

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Alexandria

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	28	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	28	4	NTU	0	< 0.30	0.30	0.30
Odour	28	0	Dilution number	0	0	0	0
Taste	28	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	28	9.5	pH units	0	7.60	7.82	8.10
Nitrate	3	50	mgNO ₃ /l	0	< 0.50	0.92	1.68
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.03
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	28		mgC/l	0	0.70	1.14	1.90
Aluminium	28	200	µgAl/l	0	10	21.14	40
Iron	27	200	µgFe/l	0	< 6	17.30	183
Manganese	28	50	µgMn/l	0	< 2	2.29	9
Cyanide	28	50	µgCN/l	0	< 1	1.04	2
Lead	28	10	µgPb/l	0	< 0.30	0.45	2
Coliform Bacteria (Total coliforms)	48	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	48	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	28	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	28	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	48		CFU/ml	0	0	0.98	47

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Alexandria

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Free	48		mg/l	0	0.16	0.71	1.14
Residual Disinfectant - Total	48		mg/l	0	0.24	0.78	1.18
Conductivity	28	2500	µS/cm	0	69	81.75	90
Chloride	28	250	mgCl/l	0	6	7.93	10
Tetrachloro methane	28	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	28	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	28	100	µg/l	0	13.20	28.60	44.20
HAA5 Total	28	60	µg/l	0	8.50	20.46	34.40
1_2 Dichloroethane	28	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	28	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	9.70	11.13	12.80
Sodium	3	200	mgNa/l	0	4.50	8.50	11.20
Copper	3	2	mgCu/l	0	0.00	0.03	0.07
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Alexandria

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	3	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00