

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Amlaird Milngavie Gorbals Zone RSZ

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	28	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	28	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	28	0	Dilution number	0	0	0	0
Taste	28	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	28	9.5	pH units	0	7.20	7.70	8.40
Nitrate	3	50	mgNO ₃ /l	0	0.55	1.39	2.13
Nitrite	28	0.5	mgNO ₂ /l	0	< 0.02	0.04	0.21
Nitrite/Nitrate formula	3		Unitless	0	0.03	0.05	0.08
Ammonium (total)	28	0.5	mg/l as NH ₄	0	0.19	0.28	0.33
Aluminium	28	200	µgAl/l	0	13	34.07	65
Iron	29	200	µgFe/l	0	< 6	43.38	160
Manganese	28	50	µgMn/l	0	< 2	3.93	9
Lead	28	10	µgPb/l	0	< 0.30	0.31	0.50
Coliform Bacteria (Total coliforms)	108	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	108	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	28	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	28	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	107		CFU/ml	0	0	0.43	17
Residual Disinfectant - Free	109		mg/l	0	< 0.04	0.05	0.09
Residual Disinfectant - Total	109		mg/l	0	0.33	0.88	1.22

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Amlaird Milngavie Gorbals Zone RSZ

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Conductivity	28	2500	µS/cm	0	67	124.82	181
Chloride	28	250	mgCl/l	0	7	10.36	15
Chlorate	28	0.25	mg/l	0	< 0.01	0.08	0.24
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENO L A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	18.60	22.60	25.10
Sodium	3	200	mgNa/l	0	5.80	6.07	6.40
Total organic carbon	3		mgC/l	0	1.40	1.60	1.80
Copper	3	2	mgCu/l	0	< 0.00	0.02	0.04
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	0.20	0.27	0.30
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	3	50	µgCN/l	0	< 1	4	6
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	0.03	0.04
Nickel	3	20	µgNi/l	0	< 0.80	1.73	3.60
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Amlaird Milngavie Gorbals Zone RSZ

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	14.20	32.43	49.10
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	3	60	µg/l	0	9.30	20.97	29
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05