

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Assynt

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	49	20	mg/l Pt/Co	0	< 2	2.20	8
Turbidity	49	4	NTU	0	< 0.30	0.31	0.70
Odour	49	0	Dilution number	0	0	0	0
Taste	49	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	49	9.5	pH units	0	7	7.69	8.40
Nitrite	49	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.14
Ammonium (total)	49	0.5	mg/l as NH ₄	0	0.17	0.33	0.41
Aluminium	49	200	µgAl/l	0	11	27.63	46
Iron	49	200	µgFe/l	2.04	< 6	25.08	364
Manganese	49	50	µgMn/l	0	< 2	2.04	4
Lead	49	10	µgPb/l	2.04	< 0.30	0.57	12.60
Coliform Bacteria (Total coliforms)	96	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	96	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	48	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	49	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	95		CFU/ml	0	0	0.27	11
Residual Disinfectant - Free	96		mg/l	0	< 0.04	0.07	0.13
Residual Disinfectant - Total	96		mg/l	0	0.17	1.06	1.29
Conductivity	49	2500	µS/cm	0	51	54.20	56
Chloride	49	250	mgCl/l	0	11	11.94	13

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Assynt

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	2.20	2.25	2.30
Sodium	4	200	mgNa/l	0	5	5.30	5.50
Nitrate	4	50	mgNO3/l	0	0.63	0.75	0.85
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.02
Copper	4	2	mgCu/l	0	0.00	0.02	0.04
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1.75	3
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	4	0.25	mg/l	0	0.10	0.14	0.16
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	4	60	µg/l	0	8.30	10.55	13.20
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Assynt

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Total organic carbon	4		mgC/l	0	1.20	1.45	1.60
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	4	100	µg/l	0	9.80	13.70	16.30
1_2 Dichloroeth ane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08