

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Auchneel

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Coliform Bacteria (Total coliforms)	24	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	24	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	24		CFU/ml	0	0	0	0
Residual Disinfectant - Free	24		mg/l	0	< 0.04	0.05	0.08
Residual Disinfectant - Total	24		mg/l	0	0.73	1.06	1.29
Colour	10	20	mg/l Pt/Co	0	2	3.50	5
Turbidity	10	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	10	0	Dilution number	0	0	0	0
Taste	10	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	10	9.5	pH units	0	7.60	8.01	9
Sulphate	2	250	mgSO4/l	0	54.70	59.15	63.60
Sodium	2	200	mgNa/l	0	37.10	41.15	45.20
Nitrate	2	50	mgNO3/l	0	0.75	1.73	2.71
Nitrite	10	0.5	mgNO2/l	0	< 0.02	0.02	0.03
Nitrite/Nitrate formula	2		Unitless	0	0.02	0.04	0.05
Ammonium (total)	10	0.5	mg/l as NH4	0	0.31	0.34	0.37
Aluminium	10	200	µgAl/l	0	9	22.10	48
Iron	10	200	µgFe/l	0	6	12	27
Manganese	10	50	µgMn/l	0	< 2	2	2
Copper	2	2	mgCu/l	0	0.00	0.02	0.03

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Auchneel

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	2	10	µgAs/l	0	0.20	0.20	0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	2	50	µgCN/l	0	4	5.50	7
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	1	1	1
Lead	2	10	µgPb/l	0	< 0.30	0.30	0.30
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Enterococci (Faecal streptococci)	10	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	10	0	CFU/100ml	0	0	0	0
Conductivity	10	2500	µS/cm	0	138	243.10	303
Chloride	10	250	mgCl/l	0	26	31	35
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	2	0.25	mg/l	0	0.08	0.14	0.19
Chlorite	10	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	2	60	µg/l	0	13.90	22.55	31.20
Bromate	10	10	µgBrO3/l	0	< 0.90	0.94	1.30
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Auchneel

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Beta Activity	2		Bq/l	0	0.04	0.06	0.07
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	10	1	µg/l	0	< 0.05	< 0.05	< 0.05
Total organic carbon	2		mgC/l	0	3.70	3.95	4.20
Tetrachloro methane	2	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	2	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	2	100	µg/l	0	40.20	42.30	44.40
1_2 Dichloroethane	2	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	2	1	µg/l	0	< 0.08	< 0.08	< 0.08
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	1	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	1	0.01	µg/l	0	< 0.00	< 0.00	< 0.00