

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Aviemore

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	22	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.70	7.95	8.10
Nitrite	22	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.07
Ammonium (total)	22	0.5	mg/l as NH ₄	0	0.14	0.18	0.22
Aluminium	22	200	µgAl/l	0	< 8	8.82	26
Iron	22	200	µgFe/l	0	< 6	8.05	41
Manganese	22	50	µgMn/l	0	< 2	2.36	9
Lead	22	10	µgPb/l	0	< 0.30	0.37	1.60
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	36	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	36	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	35		CFU/ml	0	0	11.49	300
Residual Disinfectant - Free	36		mg/l	0	< 0.04	0.06	0.12
Residual Disinfectant - Total	36		mg/l	0	0.59	0.69	0.81
Conductivity	22	2500	µS/cm	0	154	160	171

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Aviemore

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	22	250	mgCl/l	0	17	18.73	22
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	21	0.25	mg/l	0	0.04	0.07	0.11
Microcystin LR	22	1	µg/l	0	< 0.05	< 0.05	< 0.05
HAA5 Total	3	60	µg/l	0	< 1.90	< 1.90	< 1.90
Sulphate	3	250	mgSO4/l	0	5.10	5.20	5.30
Sodium	3	200	mgNa/l	0	11.20	12.13	13.30
Total organic carbon	3		mgC/l	0	0.50	0.50	0.50
Copper	3	2	mgCu/l	0	0.00	0.01	0.01
Fluoride	3	1.5	mgF/l	0	0.25	0.32	0.42
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	0.02	0.03	0.03
Cyanide	3	50	µgCN/l	0	< 1	1.33	2
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Aviemore

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloroethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	< 4.90	< 4.90	< 4.90
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	0.90	0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	0.04	0.04
Uranium	3	30	µgU/l	0	0.17	0.18	0.19
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	3	50	mgNO3/l	0	2.86	2.88	2.90
Nitrite/Nitrate formula	3		Unitless	0	0.06	0.06	0.06