

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badachro

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Coliform Bacteria (Total coliforms)	12	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	12	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	4	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	4	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	12		CFU/ml	0	0	0	0
Residual Disinfectant - Free	12		mg/l	0	0.53	0.64	0.82
Residual Disinfectant - Total	12		mg/l	0	0.57	0.67	0.86
Total organic carbon	1		mgC/l	0	< 0.50	< 0.50	< 0.50
Lead	4	10	µgPb/l	0	< 0.30	0.43	0.60
Tetrachloro methane	1	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	1	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	1	100	µg/l	0	10.10	10.10	10.10
1_2 Dichloroeth ane	1	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	1	1	µg/l	0	< 0.08	< 0.08	< 0.08
Colour	4	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	4	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	4	0	Dilution number	0	0	0	0
Taste	4	0	Dilution number	0	0	0	0

Hydrogen ion (pH)	4	9.5	pH units	0	7.30	7.43	7.60
Aluminium	4	200	µgAl/l	0	< 8	< 8	< 8

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badachro

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Iron	4	200	µgFe/l	0	6	6.50	7
Manganese	4	50	µgMn/l	0	< 2	< 2	< 2
PAH - Sum Of 4 Substances	1	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Conductivity	4	2500	µS/cm	0	43	46.25	49
Chloride	4	250	mgCl/l	0	10	10	10
Benzo 3_4 Pyrene	1	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Sulphate	1	250	mgSO4/l	0	0.50	0.50	0.50
Sodium	1	200	mgNa/l	0	6.10	6.10	6.10
Copper	1	2	mgCu/l	0	0.01	0.01	0.01
Fluoride	1	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	1	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	1	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	1	50	µgCN/l	0	1	1	1
Chromium	1	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	1	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	1	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	1	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	1	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	1	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	1	0.25	mg/l	0	0.04	0.04	0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badachro

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chlorite	1	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	1	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	1		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	1		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	1	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Nitrate	1	50	mgNO3/l	0	< 0.50	< 0.50	< 0.50
Nitrite	1	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	1		Unitless	0	0	0	0
Ammonium (total)	1	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	1	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
HAA5 Total	1	60	µg/l	0	25.50	25.50	25.50
Microcystin LR	1	1	µg/l	0	< 0.05	< 0.05	< 0.05