

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badentinan

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	52	20	mg/l Pt/Co	0	< 2	2.52	7
Turbidity	52	4	NTU	0	< 0.30	0.32	0.70
Odour	51	0	Dilution number	1.96	0	0.10	5
Taste	51	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	52	9.5	pH units	0	8	8.20	9
Sulphate	4	250	mgSO4/l	0	6.80	18.28	33.60
Sodium	4	200	mgNa/l	0	12.30	19.80	27.80
Nitrite	52	0.5	mgNO2/l	0	< 0.02	0.05	0.21
Ammonium (total)	52	0.5	mg/l as NH4	0	0.19	0.30	0.37
Total organic carbon	52		mgC/l	0	1.10	1.40	2.60
Aluminium	52	200	µgAl/l	0	< 8	10.40	22
Iron	52	200	µgFe/l	0	< 6	13.06	173
Manganese	52	50	µgMn/l	0	2	3.10	13
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.01
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	52	50	µgCN/l	0	< 1	2.10	4
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	0.83	0.90

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badentinan

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Lead	52	10	µgPb/l	0	< 0.30	0.76	9.90
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	83	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	83	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	52	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	51	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	83		CFU/ml	0	0	0.27	7
Residual Disinfectant - Free	84		mg/l	0	< 0.04	0.05	0.12
Residual Disinfectant - Total	84		mg/l	0	0.80	1.18	1.54
Conductivity	52	2500	µS/cm	0	179	206.46	283
Chloride	52	250	mgCl/l	0	14	20.10	26
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	52	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	52	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	52	100	µg/l	0	11.80	16.77	25.30
Chlorate	52	0.25	mg/l	0	0.01	0.12	0.24
Chlorite	52	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	52	60	µg/l	0	6.80	12.66	23.80
1,2 Dichloroethane	52	3	µg/l	0	< 0.09	< 0.09	< 0.09

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Badentinan

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Benzene	52	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	52	10	µgBrO3/l	0	< 0.90	0.92	1.60
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	0.05	0.05	0.06
Uranium	4	30	µgU/l	0	< 0.04	0.07	0.09
Microcystin LR	52	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Nitrate	4	50	mgNO3/l	0	1.91	7.49	12.71
Nitrite/Nitrate formula	4		Unitless	0	0.09	0.17	0.25
Fluoride	3	1.5	mgF/l	0	< 0.12	0.12	0.14