

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	19	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	19	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	19	0	Dilution number	0	0	0	0
Taste	19	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	19	9.5	pH units	0	7.40	7.56	7.90
Aluminium	19	200	µgAl/l	0	< 8	13.84	58
Iron	19	200	µgFe/l	0	< 6	19.21	119
Manganese	19	50	µgMn/l	0	< 2	2.05	3
Lead	19	10	µgPb/l	0	< 0.30	0.38	1.10
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	71	0	CFU/100ml	1.41	0	0.01	1
E. coli (Faecal coliforms)	71	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	19	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	19	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	72		CFU/ml	0	0	0.11	2
Residual Disinfectant - Free	72		mg/l	0	< 0.04	0.47	0.81
Residual Disinfectant - Total	72		mg/l	0	0.10	0.55	0.93
Conductivity	19	2500	µS/cm	0	55	61.63	78
Chloride	19	250	mgCl/l	0	5	6.16	8
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chlorate	19	0.25	mg/l	0	0.06	0.10	0.15
HAA5 Total	3	60	µg/l	0	21.40	23.80	25.20
Sulphate	3	250	mgSO4/l	0	8.80	10.23	12
Sodium	3	200	mgNa/l	0	3.80	4.37	5.10
Nitrate	3	50	mgNO3/l	0	< 0.50	0.69	0.88
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Total organic carbon	3		mgC/l	0	1	1.20	1.40
Copper	3	2	mgCu/l	0	0.00	0.01	0.01
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.03	0.04
Cyanide	3	50	µgCN/l	0	< 1	1	1
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore A

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	27.40	36.53	46.70
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
Pesticides - Total Substances	3	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01