

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	46	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	46	4	NTU	0	< 0.30	0.30	0.30
Odour	46	0	Dilution number	0	0	0	0
Taste	46	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	46	9.5	pH units	0	7.40	7.62	7.80
Sulphate	4	250	mgSO ₄ /l	0	8.80	9.88	11.80
Sodium	4	200	mgNa/l	0	3.70	4	4.70
Aluminium	46	200	µgAl/l	0	9	13.02	38
Iron	46	200	µgFe/l	0	< 6	18.67	161
Manganese	46	50	µgMn/l	0	< 2	2.09	6
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	0.03	0.06
Nickel	4	20	µgNi/l	0	< 0.80	0.95	1.40
Lead	46	10	µgPb/l	2.17	< 0.30	0.87	10.10
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	179	0	CFU/100ml	1.12	0	0.02	2
E. coli (Faecal coliforms)	179	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	46	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	46	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	180		CFU/ml	0	0	1	63
Residual Disinfectant - Free	180		mg/l	0	< 0.04	0.39	1.40
Residual Disinfectant - Total	180		mg/l	0	< 0.04	0.46	1.50
Conductivity	46	2500	µS/cm	0	53	63.17	85
Chloride	46	250	mgCl/l	0	5	6.07	9
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	46	0.25	mg/l	0	< 0.01	0.08	0.19
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	3	50	mgNO3/l	0	0.57	0.67	0.73
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrite/Nitrate formula	3		Unitless	0	0.01	0.01	0.01
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Total organic carbon	4		mgC/l	0	1.10	1.13	1.20
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	23.40	28.78	35.40
HAA5 Total	4	60	µg/l	0	13.60	16.73	19.70
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01