

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	52	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	52	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	52	0	Dilution number	0	0	0	0
Taste	52	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	52	9.5	pH units	0	7.30	7.62	8
Total organic carbon	4		mgC/l	0	1	1.10	1.20
Aluminium	51	200	µgAl/l	0	< 8	12.71	45
Iron	51	200	µgFe/l	0	< 6	17.24	192
Manganese	51	50	µgMn/l	0	< 2	2.10	5
Lead	52	10	µgPb/l	0	< 0.30	0.42	1.90
Coliform Bacteria (Total coliforms)	203	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	203	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	52	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	52	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	203		CFU/ml	0	0	0.31	19
Residual Disinfectant - Free	204		mg/l	0	< 0.04	0.43	0.81
Residual Disinfectant - Total	204		mg/l	0	0.06	0.50	1.01
Conductivity	52	2500	µS/cm	0	53	62.85	91
Chloride	52	250	mgCl/l	0	5	6.04	8
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	21.80	30.33	34.80
Chlorate	52	0.25	mg/l	0	< 0.01	0.09	0.19
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	8.70	9.97	11.90
Sodium	4	200	mgNa/l	0	3.80	4.10	4.80
Nitrate	4	50	mgNO3/l	0	0.58	0.87	1.46
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.03
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1	1

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	0.06	0.17
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	4	60	µg/l	0	12.30	20.83	30
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Pesticides - Total Substances	5	0.5	µg/l	0	0	0	0
	4			0	< 0.01	< 0.01	< 0.01
	4			0	< 0.01	< 0.01	< 0.01