

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 North

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	46	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	46	4	NTU	0	< 0.30	0.31	0.60
Odour	46	0	Dilution number	0	0	0	0
Taste	46	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	46	9.5	pH units	0	7.40	7.60	8
Total organic carbon	46		mgC/l	0	1	1.15	1.50
Aluminium	46	200	µgAl/l	0	8	12.54	27
Iron	46	200	µgFe/l	2.17	< 6	34.09	356
Manganese	46	50	µgMn/l	0	< 2	2.50	23
Cyanide	46	50	µgCN/l	0	< 1	1	1
Lead	46	10	µgPb/l	2.17	< 0.30	0.82	17.30
Coliform Bacteria (Total coliforms)	180	0	CFU/100ml	1.11	0	0.02	2
E. coli (Faecal coliforms)	180	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	46	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	46	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	179		CFU/ml	0	0	0.90	125
Residual Disinfectant - Free	180		mg/l	0	< 0.04	0.46	0.87
Residual Disinfectant - Total	180		mg/l	0	< 0.04	0.54	0.99
Conductivity	46	2500	µS/cm	0	53	62.13	83
Chloride	46	250	mgCl/l	0	5	6.15	8

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 North

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	46	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	46	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	46	100	µg/l	0	17.30	27.66	38.70
Chlorate	46	0.25	mg/l	0	0.05	0.08	0.16
HAA5 Total	46	60	µg/l	0	< 1.90	17.35	31.90
1_2 Dichloroethane	46	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	46	1	µg/l	0	< 0.08	< 0.08	< 0.08
Sulphate	4	250	mgSO4/l	0	8.60	10.33	12.20
Sodium	4	200	mgNa/l	0	3.80	4.23	4.50
Nitrate	4	50	mgNO3/l	0	0.52	0.93	1.58
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.03
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.02
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 North

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01