

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 South

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	0.31	0.50
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.40	7.60	7.90
Sulphate	4	250	mgSO4/l	0	8.70	9.93	11.60
Sodium	4	200	mgNa/l	0	3.70	4.08	4.60
Aluminium	37	200	µgAl/l	0	9	13.41	17
Iron	37	200	µgFe/l	0	< 6	11.95	108
Manganese	37	50	µgMn/l	0	< 2	2.08	5
Copper	4	2	mgCu/l	0	0.00	0.01	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	37	10	µgPb/l	0	< 0.30	0.30	0.30
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 South

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	143		CFU/ml	0	0	2.39	300
Residual Disinfectant - Free	144		mg/l	0	< 0.04	0.47	0.96
Residual Disinfectant - Total	144		mg/l	0	0.08	0.55	0.99
Conductivity	37	2500	µS/cm	0	53	63.24	82
Chloride	37	250	mgCl/l	0	5	6.19	8
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	37	0.25	mg/l	0	0.05	0.08	0.15
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	1	1.20
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	4	50	mgNO3/l	0	0.57	1.42	3.22
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.03	0.06
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore C5 South

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Total organic carbon	4		mgC/l	0	0.90	1.13	1.30
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	22.60	26.65	34.40
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
HAA5 Total	4	60	µg/l	0	18.90	21.03	23.20
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	3			0	< 0.01	< 0.01	< 0.01
	3			0	< 0.01	< 0.01	< 0.01