

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Carron Valley

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	40	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	0	7.50	7.79	8.60
Sulphate	4	250	mgSO4/l	0	9.10	14.03	20.60
Sodium	4	200	mgNa/l	0	3.90	5.15	7.20
Total organic carbon	40		mgC/l	0	1.10	1.44	1.90
Aluminium	39	200	µgAl/l	0	8	18.97	42
Iron	39	200	µgFe/l	0	< 6	30.67	127
Manganese	39	50	µgMn/l	0	< 2	2.49	7
Copper	4	2	mgCu/l	0	0.00	0.01	0.04
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	40	50	µgCN/l	0	< 1	1.05	2
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	40	10	µgPb/l	0	< 0.30	0.33	0.90

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Carron Valley

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	156	0	CFU/100ml	0.64	0	0.01	1
E. coli (Faecal coliforms)	156	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	2.50	0	0.03	1
Colony Counts After 3 Days At 22°C	155		CFU/ml	0	0	0.35	47
Residual Disinfectant - Free	156		mg/l	0	< 0.04	0.37	0.80
Residual Disinfectant - Total	156		mg/l	0	< 0.04	0.46	0.83
Conductivity	40	2500	µS/cm	0	54	83.18	110
Chloride	40	250	mgCl/l	0	5	7.23	9
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	40	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	40	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	40	100	µg/l	0	22.60	42.89	59.80
Chlorate	40	0.25	mg/l	0	0.04	0.08	0.13
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	39	60	µg/l	0	15.20	26.25	49.10
1,2 Dichloroethane	40	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	40	1	µg/l	0	< 0.08	< 0.08	< 0.08

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Carron Valley

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	39	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	3	50	mgNO3/l	0	< 0.50	0.77	1.31
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.03
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01