

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore E

Page 1 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	22	4	NTU	0	< 0.30	0.30	0.30
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.50	7.95	9.10
Nitrate	3	50	mgNO ₃ /l	0	0.70	0.73	0.78
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0.01	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	22		mgC/l	0	1	1.18	1.40
Aluminium	22	200	µgAl/l	0	9	16.18	24
Iron	22	200	µgFe/l	0	< 6	11.68	45
Manganese	22	50	µgMn/l	0	< 2	3.05	25
Cyanide	22	50	µgCN/l	0	< 1	1	1
Lead	22	10	µgPb/l	0	< 0.30	0.35	1.20
Coliform Bacteria (Total coliforms)	83	0	CFU/100ml	1.20	0	0.01	1
E. coli (Faecal coliforms)	83	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	84		CFU/ml	0	0	0.26	11

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore E

Page 2 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Free	84		mg/l	0	0.18	0.48	0.89
Residual Disinfectant - Total	84		mg/l	0	0.25	0.58	0.99
Conductivity	22	2500	µS/cm	0	55	63.82	80
Chloride	22	250	mgCl/l	0	5	6.18	8
Tetrachloro methane	22	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	22	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	22	100	µg/l	0	28.60	36.74	55.10
Chlorate	22	0.25	mg/l	0	0.06	0.10	0.16
HAA5 Total	22	60	µg/l	0	15.80	22.42	31.20
1_2 Dichloroethane	22	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	22	1	µg/l	0	< 0.08	< 0.08	< 0.08
Sulphate	3	250	mgSO4/l	0	8.80	10.27	11.60
Sodium	3	200	mgNa/l	0	4.10	4.60	5.60
Copper	3	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore E

Page 3 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	1.07	1.40
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
Pesticides - Total Substances	6	0.5	µg/l	0	0	0	0
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENO L A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
2 4-D	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPP(Mec oprop)	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	3	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	3	0.1	µg/l	0	< 0.01	< 0.01	0.02
2 4-Db	3	0.1	µg/l	0	< 0.01	< 0.01	0.02
	1			0	< 0.01	< 0.01	< 0.01

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore E

Page 4 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
	1			0	< 0.01	< 0.01	< 0.01