

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Legbrannock

Page 1 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	16	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	16	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	16	0	Dilution number	0	0	0	0
Taste	16	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	16	9.5	pH units	0	7.30	7.57	7.80
Aluminium	16	200	µgAl/l	0	10	17.06	38
Iron	16	200	µgFe/l	0	< 6	7.44	19
Manganese	16	50	µgMn/l	0	< 2	2.31	6
Lead	16	10	µgPb/l	0	< 0.30	0.32	0.60
Coliform Bacteria (Total coliforms)	60	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	60	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	16	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	16	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	60		CFU/ml	0	0	0	0
Residual Disinfectant - Free	60		mg/l	0	0.13	0.51	1
Residual Disinfectant - Total	60		mg/l	0	0.19	0.59	1.13
Conductivity	16	2500	µS/cm	0	55	64.75	90
Chloride	16	250	mgCl/l	0	5	6.06	7
Chlorate	16	0.25	mg/l	0	< 0.01	0.10	0.24
Sulphate	2	250	mgSO4/l	0	11.70	14.05	16.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Legbrannock

Page 2 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Sodium	2	200	mgNa/l	0	4.30	4.90	5.50
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Cyanide	2	50	µgCN/l	0	1	1	1
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO3/l	0	< 0.90	1.05	1.20
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
HAA5 Total	2	60	µg/l	0	21.90	22.60	23.30
Copper	2	2	mgCu/l	0	< 0.00	0.00	0.00
Arsenic	2	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	2	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Nitrate	2	50	mgNO3/l	0	0.70	0.71	0.71
Nitrite	2	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Legbrannock

Page 3 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrite/Nitrate formula	2		Unitless	0	0.01	0.01	0.01
Ammonium (total)	2	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Total organic carbon	2		mgC/l	0	1.10	1.10	1.10
Pesticides - Total Substances	4	0.5	µg/l	0	0	0.00	0.01
Tetrachloro methane	2	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	2	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	2	100	µg/l	0	33.20	36.60	40
1,2-Dichloroethane	2	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	2	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	2	1	µg/l	0	< 0.05	< 0.05	< 0.05
2,4-D	2	0.1	µg/l	0	< 0.01	0.01	0.01
Dicamba	2	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPP(Mecoprop)	2	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	2	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	2	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
2,4-Db	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo[a]pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
	1			0	< 0.01	< 0.01	< 0.01

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Balmore Legbrannock

Page 4 of 4

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
	1			0	< 0.01	< 0.01	< 0.01