

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Belmore

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	22	4	NTU	0	< 0.30	0.30	0.40
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.10	7.67	8.60
Total organic carbon	22		mgC/l	0	0.50	0.93	1.40
Aluminium	22	200	µgAl/l	0	9	16.77	25
Iron	22	200	µgFe/l	4.55	< 6	38.68	448
Manganese	22	50	µgMn/l	0	< 2	3.41	18
Cyanide	22	50	µgCN/l	0	< 1	1.05	2
Lead	22	10	µgPb/l	0	< 0.30	0.30	0.30
Coliform Bacteria (Total coliforms)	24	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	24	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	24		CFU/ml	0	0	0.33	5
Residual Disinfectant - Free	24		mg/l	0	0.05	0.69	1.06
Residual Disinfectant - Total	24		mg/l	0	0.07	0.77	1.10
Conductivity	22	2500	µS/cm	0	50	66.23	78
Chloride	22	250	mgCl/l	0	5	6.91	12

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Belmore

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	22	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	22	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	22	100	µg/l	0	10.40	25.77	47.30
HAA5 Total	19	60	µg/l	0	6.30	20.73	52.90
1_2 Dichloroethane	22	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	22	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	22	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	9.90	11.47	13.30
Sodium	3	200	mgNa/l	0	2.90	3.60	4.50
Copper	3	2	mgCu/l	0	0.01	0.01	0.02
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	0.04	0.09
Nickel	3	20	µgNi/l	0	< 0.80	1.07	1.60
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Belmore

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	3	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Nitrate	3	50	mgNO3/l	0	< 0.50	< 0.50	< 0.50
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0	0
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04