

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Black Esk

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	25	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	25	4	NTU	0	< 0.30	0.30	0.40
Odour	25	0	Dilution number	0	0	0	0
Taste	25	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	25	9.5	pH units	0	7.70	7.89	8.10
Sulphate	3	250	mgSO ₄ /l	0	26.90	29.90	32.50
Sodium	3	200	mgNa/l	0	5.30	6.57	8.30
Nitrate	2	50	mgNO ₃ /l	0	1.52	1.64	1.76
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	2		Unitless	0	0.03	0.04	0.04
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	25		mgC/l	0	1.30	1.80	2.30
Aluminium	25	200	µgAl/l	0	11	32.08	58
Iron	25	200	µgFe/l	0	< 6	16.52	125
Manganese	25	50	µgMn/l	0	< 2	3.80	14
Copper	3	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	25	50	µgCN/l	0	< 1	1	1

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Black Esk

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	3	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	96	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	96	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	25	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	25	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	96		CFU/ml	0	0	0.05	2
Residual Disinfectant - Free	95		mg/l	0	< 0.04	0.42	1.11
Residual Disinfectant - Total	95		mg/l	0	0.15	0.52	1.23
Conductivity	25	2500	µS/cm	0	143	178.68	302
Chloride	25	250	mgCl/l	0	7	9.56	19
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	25	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	25	10	µg/l	0	< 0.52	< 0.52	< 0.52

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Black Esk

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Total Trihalomethanes	25	100	µg/l	0	27	48.32	76.10
Chlorate	25	0.25	mg/l	0	0.04	0.11	0.25
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	25	60	µg/l	0	19.60	31.25	53.50
1_2 Dichloroethane	25	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	25	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	25	1	µg/l	0	< 0.05	< 0.05	< 0.05
Pesticides - Total Substances	3	0.5	µg/l	0	0	0.00	0.01
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
2_4-D	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPP(Mecoprop)	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	3	0.1	µg/l	0	< 0.00	0.01	0.01
MCPB	3	0.1	µg/l	0	< 0.01	< 0.01	0.02
2_4-Db	3	0.1	µg/l	0	< 0.01	< 0.01	0.02