

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Blairlinnans South

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	43	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	43	4	NTU	0	< 0.30	0.30	0.40
Odour	43	0	Dilution number	0	0	0	0
Taste	43	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	43	9.5	pH units	0	7.40	7.98	8.70
Total organic carbon	43		mgC/l	0	1	1.27	1.90
Aluminium	43	200	µgAl/l	0	13	31.44	53
Iron	43	200	µgFe/l	0	< 6	10.58	40
Manganese	43	50	µgMn/l	0	< 2	2.14	7
Cyanide	43	50	µgCN/l	0	< 1	1	1
Lead	43	10	µgPb/l	0	< 0.30	0.39	2.10
Coliform Bacteria (Total coliforms)	168	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	168	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	43	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	43	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	167		CFU/ml	0	0	0.08	5
Residual Disinfectant - Free	168		mg/l	0	0.07	0.60	1.01
Residual Disinfectant - Total	168		mg/l	0	0.09	0.69	1.12
Conductivity	43	2500	µS/cm	0	72	76.26	128
Chloride	43	250	mgCl/l	0	7	8.09	10

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Blairlinnans South

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	43	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	43	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	43	100	µg/l	0	29.70	43.11	56.20
HAA5 Total	42	60	µg/l	0	12.20	24.62	33.90
1_2 Dichloroethane	43	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	43	1	µg/l	0	< 0.08	< 0.08	< 0.08
Sulphate	4	250	mgSO4/l	0	9.30	9.70	10.20
Sodium	4	200	mgNa/l	0	4.10	4.28	4.50
Nitrate	4	50	mgNO3/l	0	0.66	0.85	1.11
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.33	0.70
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Blairlinnans South

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	4	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13