

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan C

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	37	4	NTU	0	< 0.30	0.31	0.50
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7	7.47	7.80
Sulphate	4	250	mgSO ₄ /l	0	19.10	20.63	22.50
Sodium	4	200	mgNa/l	0	5	5.93	6.60
Nitrite	37	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Ammonium (total)	37	0.5	mg/l as NH ₄	0	0.24	0.30	0.33
Total organic carbon	37		mgC/l	0	1.40	1.85	2.30
Aluminium	37	200	µgAl/l	0	15	27.16	41
Iron	37	200	µgFe/l	0	< 6	18.78	92
Manganese	37	50	µgMn/l	0	< 2	3	7
Copper	4	2	mgCu/l	0	0.01	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	0.20	0.25	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	37	50	µgCN/l	0	2	4.24	7
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan C

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	37	10	µgPb/l	0	< 0.30	0.37	1.10
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	144		CFU/ml	0	0	0.32	29
Residual Disinfectant - Free	145		mg/l	0	< 0.04	0.06	0.13
Residual Disinfectant - Total	145		mg/l	0	0.61	1.02	1.34
Conductivity	37	2500	µS/cm	0	80	91.32	103
Chloride	37	250	mgCl/l	0	8	9.51	11
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	37	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	37	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	37	100	µg/l	0	25.50	40.84	62
Chlorate	37	0.25	mg/l	0	0.03	0.10	0.25
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	37	60	µg/l	0	17	25.33	35.30

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan C

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
1_2 Dichloroethane	37	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	37	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	4	10	µgBrO ₃ /l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	37	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Nitrate	3	50	mgNO ₃ /l	0	0.69	1.04	1.44
Nitrite/Nitrate formula	3		Unitless	0	0.01	0.02	0.03