

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan Milngavie Gorbals Zone RSZ

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	61	20	mg/l Pt/Co	0	< 2	2.03	3
Turbidity	61	4	NTU	0	< 0.30	0.31	0.90
Odour	61	0	Dilution number	1.64	0	0.07	4
Taste	61	0	Dilution number	1.64	0	1.62	99
Hydrogen ion (pH)	61	9.5	pH units	0	7	7.48	8
Nitrate	4	50	mgNO ₃ /l	0	0.67	0.98	1.21
Nitrite	61	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.34
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.02
Ammonium (total)	61	0.5	mg/l as NH ₄	0	0.10	0.29	0.43
Total organic carbon	61		mgC/l	0	1.40	1.84	2.40
Aluminium	61	200	µgAl/l	0	9	26.51	40
Iron	61	200	µgFe/l	1.64	< 6	21.95	483
Manganese	61	50	µgMn/l	0	< 2	3.51	10
Cyanide	61	50	µgCN/l	0	< 1	4.25	7
Lead	61	10	µgPb/l	0	< 0.30	0.51	5.70
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	239	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	239	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	61	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	61	0	CFU/100ml	0	0	0	0

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan Milngavie Gorbals Zone RSZ

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colony Counts After 3 Days At 22øc	238		CFU/ml	0	0	0.30	20
Residual Disinfectant - Free	238		mg/l	0	< 0.04	0.06	0.16
Residual Disinfectant - Total	239		mg/l	0	0.09	0.96	1.24
Conductivity	61	2500	µS/cm	0	80	91.10	105
Chloride	61	250	mgCl/l	0	8	9.46	11
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	61	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	61	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	61	100	µg/l	0	27.20	42.26	58.30
Chlorate	61	0.25	mg/l	6.56	0.03	0.10	0.27
HAA5 Total	61	60	µg/l	0	15.90	25.53	39
1_2 Dichloroethane	61	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	61	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	61	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	18.90	20.85	22.50
Sodium	4	200	mgNa/l	0	5.90	6.10	6.30
Copper	4	2	mgCu/l	0	0.00	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	0.20	0.23	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Bradan Milngavie Gorbals Zone RSZ

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	1	1.30
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13