

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camphill

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	76	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	76	4	NTU	0	< 0.30	0.30	0.30
Odour	76	0	Dilution number	0	0	0	0
Taste	76	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	76	9.5	pH units	0	7.40	7.77	8.40
Total organic carbon	76		mgC/l	0	1.20	1.72	2.40
Aluminium	75	200	µgAl/l	0	< 8	14.99	32
Iron	75	200	µgFe/l	0	< 6	7.51	75
Manganese	75	50	µgMn/l	0	< 2	4	15
Cyanide	76	50	µgCN/l	0	< 1	1.01	2
Lead	76	10	µgPb/l	1.32	< 0.30	0.90	36.70
Coliform Bacteria (Total coliforms)	108	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	108	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	76	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	76	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	107		CFU/ml	0	0	0.85	42
Residual Disinfectant - Free	108		mg/l	0	0.10	0.54	0.93
Residual Disinfectant - Total	108		mg/l	0	0.18	0.63	1.22
Conductivity	76	2500	µS/cm	0	107	122.62	135
Chloride	76	250	mgCl/l	0	9	14.34	18

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camphill

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	76	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	76	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	76	100	µg/l	0	29.40	55.21	98.30
Chlorate	76	0.25	mg/l	3.95	0.04	0.12	0.30
HAA5 Total	76	60	µg/l	0	13	34.00	58.40
1_2 Dichloroethane	76	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	76	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	5	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	5	250	mgSO4/l	0	20.60	23.24	26
Sodium	5	200	mgNa/l	0	6.60	9.12	10.20
Nitrate	5	50	mgNO3/l	0	0.58	0.77	1.24
Nitrite	5	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	5		Unitless	0	0.01	0.01	0.02
Ammonium (total)	5	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	5	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	5	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	5	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	5	5	µgCd/l	0	< 0.02	0.02	0.03
Chromium	5	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	5	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camphill

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	5	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	5	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	5	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	5	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	5	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	5	10	µgBrO3/l	0	< 0.90	0.98	1.20
Gross Alpha Activity	5		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	5		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	5	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	5	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	5	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	5	2.5	µg/l	0	< 0.13	< 0.13	< 0.13