

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camps

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	31	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	31	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	31	0	Dilution number	0	0	0	0
Taste	31	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	31	9.5	pH units	0	7.70	7.95	8.30
Total organic carbon	31		mgC/l	0	0.90	1.21	1.60
Aluminium	31	200	µgAl/l	0	< 8	19.48	36
Iron	31	200	µgFe/l	0	< 6	14.81	51
Manganese	31	50	µgMn/l	0	< 2	3.16	13
Cyanide	31	50	µgCN/l	0	< 1	1	1
Lead	31	10	µgPb/l	0	< 0.30	0.38	2
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	120	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	120	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	31	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	32	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	119		CFU/ml	0	0	0.44	23
Residual Disinfectant - Free	120		mg/l	0	0.04	0.43	0.84
Residual Disinfectant - Total	120		mg/l	0	0.07	0.51	0.94
Conductivity	31	2500	µS/cm	0	84	106.10	121

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camps

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	31	250	mgCl/l	0	5	7.06	13
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	31	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	31	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	31	100	µg/l	0	19.40	40.17	61.30
Chlorate	31	0.25	mg/l	3.23	< 0.01	0.05	0.83
HAA5 Total	31	60	µg/l	0	13.30	22.18	33.70
1_2 Dichloroethane	31	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	31	1	µg/l	0	< 0.08	< 0.08	< 0.08
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	14.40	16.20	19.50
Sodium	3	200	mgNa/l	0	4.50	4.53	4.60
Copper	3	2	mgCu/l	0	0.00	0.01	0.02
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Camps

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Nitrate	3	50	mgNO3/l	0	0.54	0.82	1.02
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0.01	0.02	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05