

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Carron Valley B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	52	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	52	4	NTU	0	< 0.30	0.32	0.90
Odour	52	0	Dilution number	0	0	0	0
Taste	51	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	52	9.5	pH units	0	7	7.80	8.10
Nitrate	4	50	mgNO ₃ /l	0	< 0.50	0.65	0.92
Nitrite	4	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	52		mgC/l	0	< 0.50	1.61	2.10
Aluminium	52	200	µgAl/l	0	9	23.88	64
Iron	52	200	µgFe/l	0	< 6	18.29	153
Manganese	52	50	µgMn/l	1.92	< 2	5.29	51
Cyanide	52	50	µgCN/l	0	< 1	1	1
Lead	52	10	µgPb/l	0	< 0.30	0.32	1.20
Coliform Bacteria (Total coliforms)	203	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	203	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	52	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	52	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	203		CFU/ml	0	0	0.14	9

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Carron Valley B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Free	204		mg/l	0	0.12	0.67	1.09
Residual Disinfectant - Total	204		mg/l	0	0.22	0.77	1.18
Conductivity	52	2500	µS/cm	0	63	109.48	122
Chloride	52	250	mgCl/l	0	7	8.90	11
Tetrachloro methane	52	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	52	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	52	100	µg/l	0	24.60	46.36	66.20
Chlorate	52	0.25	mg/l	0	0.02	0.07	0.15
HAA5 Total	52	60	µg/l	0	19.90	35.16	59.20
1_2 Dichloroethane	52	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	52	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	52	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	1.60	17.68	24.60
Sodium	4	200	mgNa/l	0	6.20	8.98	17.10
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Carron Valley B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13