

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto East

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	55	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	55	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	55	0	Dilution number	0	0	0	0
Taste	55	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	55	9.5	pH units	0	7.60	7.75	8
Total organic carbon	55		mgC/l	0	1	1.31	1.70
Aluminium	55	200	µgAl/l	0	11	21	52
Iron	55	200	µgFe/l	0	< 6	8.69	25
Manganese	55	50	µgMn/l	0	< 2	2.49	10
Cyanide	55	50	µgCN/l	0	< 1	1	1
Lead	55	10	µgPb/l	0	< 0.30	0.35	1.10
Coliform Bacteria (Total coliforms)	216	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	216	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	55	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	55	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	216		CFU/ml	0	0	0.42	26
Residual Disinfectant - Free	216		mg/l	0	< 0.04	0.44	0.74
Residual Disinfectant - Total	216		mg/l	0	0.12	0.53	0.87
Conductivity	55	2500	µS/cm	0	87	98.35	111
Chloride	55	250	mgCl/l	0	5	6.91	9

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto East

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	55	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	55	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	55	100	µg/l	0	17.60	30.75	42.50
Chlorate	55	0.25	mg/l	0	0.02	0.06	0.11
HAA5 Total	55	60	µg/l	0	11	19.08	33.90
1,2 Dichloroethane	55	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	55	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	55	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	4	250	mgSO4/l	0	12.40	13.35	15
Sodium	4	200	mgNa/l	0	5.30	5.78	6.90
Copper	4	2	mgCu/l	0	0.00	0.01	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto East

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Nitrate	4	50	mgNO3/l	0	0.84	1.14	1.63
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.02	0.03
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04