

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto West_A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	40	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	0	7.60	7.76	8
Sulphate	4	250	mgSO4/l	0	11.80	12.95	15
Sodium	4	200	mgNa/l	0	5.20	5.90	6.70
Aluminium	39	200	µgAl/l	0	12	24.62	62
Iron	39	200	µgFe/l	0	< 6	9.72	61
Manganese	39	50	µgMn/l	0	< 2	3.69	27
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.02
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	40	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto West_A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	156	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	156	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	155		CFU/ml	0	0	0.57	30
Residual Disinfectant - Free	156		mg/l	0	< 0.04	0.54	1.04
Residual Disinfectant - Total	156		mg/l	0	< 0.04	0.64	1.15
Conductivity	40	2500	µS/cm	0	89	97.93	144
Chloride	40	250	mgCl/l	0	5	6.63	9
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	40	0.25	mg/l	0	0.01	0.06	0.11
HAA5 Total	4	60	µg/l	0	15.10	16.80	19.30
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	40	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	4	50	mgNO3/l	0	0.69	1.82	3.89
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Clatto West_A

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.04	0.08
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Total organic carbon	4		mgC/l	0	1.20	1.30	1.50
Tetrachloromethane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloroethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	20.80	28.35	36.50
1,2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90