

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Craigie

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	43	20	mg/l Pt/Co	0	< 2	2.09	5
Turbidity	43	4	NTU	0	< 0.30	0.30	0.40
Odour	43	0	Dilution number	2.33	0	0.05	2
Taste	43	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	43	9.5	pH units	0	7.10	7.66	8
Nitrite	43	0.5	mgNO ₂ /l	0	< 0.02	0.02	0.07
Ammonium (total)	43	0.5	mg/l as NH ₄	0	0.26	0.34	0.40
Total organic carbon	43		mgC/l	0	0.90	1.27	1.70
Aluminium	43	200	µgAl/l	0	9	22.37	44
Iron	43	200	µgFe/l	0	< 6	8	21
Manganese	43	50	µgMn/l	0	2	3.09	8
Cyanide	43	50	µgCN/l	0	< 1	2.49	7
Lead	43	10	µgPb/l	0	< 0.30	0.30	0.50
Coliform Bacteria (Total coliforms)	168	0	CFU/100ml	0.60	0	0.01	1
E. coli (Faecal coliforms)	168	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	43	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	43	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	167		CFU/ml	0	0	1.30	56
Residual Disinfectant - Free	168		mg/l	0	< 0.04	0.07	1.06
Residual Disinfectant - Total	168		mg/l	0	0.05	1.08	1.37

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Craigie

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Conductivity	43	2500	µS/cm	0	81	108.95	189
Chloride	43	250	mgCl/l	0	7	17.79	24
Tetrachloro methane	43	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	43	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	43	100	µg/l	0	8.40	12.19	20.20
Chlorate	43	0.25	mg/l	6.98	0.05	0.13	0.28
Chlorite	43	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	43	60	µg/l	0	2.90	8.50	15.90
1,2-Dichloroethane	43	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	43	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	43	10	µgBrO3/l	0	< 0.90	0.90	1.10
Microcystin LR	44	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	4.80	5.75	8.50
Sodium	4	200	mgNa/l	0	8.80	9.80	11.40
Copper	4	2	mgCu/l	0	0.00	0.01	0.02
Fluoride	4	1.5	mgF/l	0	< 0.12	0.12	0.13
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Craigie

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	0.04	0.04
Uranium	4	30	µgU/l	0	< 0.04	0.04	0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	4	50	mgNO3/l	0	1.06	1.98	3.25
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.04	0.07
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00