

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	0.30	0.40
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.40	7.83	8.20
Sulphate	4	250	mgSO ₄ /l	0	14.30	16.98	18.50
Sodium	4	200	mgNa/l	0	3.30	3.85	4.50
Total organic carbon	37		mgC/l	0	0.90	1.31	1.70
Aluminium	36	200	µgAl/l	0	< 8	33.81	113
Iron	36	200	µgFe/l	0	< 6	14.61	120
Manganese	36	50	µgMn/l	2.78	< 2	6.36	82
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	37	50	µgCN/l	0	< 1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	37	10	µgPb/l	0	< 0.30	0.48	3.10
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	143	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	143	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	143		CFU/ml	0	0	0.92	84
Residual Disinfectant - Free	144		mg/l	0	< 0.04	0.46	1.41
Residual Disinfectant - Total	144		mg/l	0	0.05	0.53	1.57
Conductivity	37	2500	µS/cm	0	80	89.03	99
Chloride	37	250	mgCl/l	0	5	6.76	8
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	37	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	37	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	37	100	µg/l	0	23.30	44.83	74.50
Chlorite	37	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	37	60	µg/l	2.70	9.80	28.05	62.40
1_2 Dichloroeth ane	37	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	37	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	37	10	µgBrO3/l	0	< 0.90	0.91	1.30
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer A

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	3	50	mgNO ₃ /l	0	< 0.50	0.56	0.69
Nitrite	4	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.00	0.01
Ammonium (total)	4	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorate	4	0.25	mg/l	0	< 0.01	0.05	0.11