

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	52	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	52	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	52	0	Dilution number	0	0	0	0
Taste	52	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	52	9.5	pH units	0	7.40	7.85	8.40
Total organic carbon	52		mgC/l	0	0.90	1.29	1.60
Aluminium	52	200	µgAl/l	0	13	32.50	53
Iron	52	200	µgFe/l	0	< 6	13.87	119
Manganese	52	50	µgMn/l	0	< 2	3.85	13
Cyanide	52	50	µgCN/l	0	< 1	1	1
Lead	51	10	µgPb/l	0	< 0.30	0.44	3.40
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	203	0	CFU/100ml	0.49	0	0.00	1
E. coli (Faecal coliforms)	203	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	52	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	52	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	203		CFU/ml	0	0	1.37	81
Residual Disinfectant - Free	204		mg/l	0	< 0.04	0.43	1.01
Residual Disinfectant - Total	204		mg/l	0	0.04	0.50	1.11
Conductivity	52	2500	µS/cm	0	82	90.60	174

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	52	250	mgCl/l	0	5	6.73	11
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	52	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	52	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	52	100	µg/l	0	20.90	42.93	70.40
Chlorite	52	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	52	60	µg/l	0	8.20	27.66	47.30
1_2 Dichloroethane	52	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	52	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	52	10	µgBrO3/l	0	< 0.90	0.90	1.10
Sulphate	4	250	mgSO4/l	0	14.60	17.08	18.80
Sodium	4	200	mgNa/l	0	3.60	3.78	4
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Daer B**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	4	0.25	mg/l	0	< 0.01	0.01	0.02
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	4	50	mgNO3/l	0	< 0.50	0.73	1.13
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13