

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer C

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	0.30	0.30
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.50	7.88	8.40
Sulphate	4	250	mgSO ₄ /l	0	14.70	17.20	19.10
Sodium	4	200	mgNa/l	0	3	3.43	3.90
Total organic carbon	37		mgC/l	0	1	1.30	1.60
Aluminium	37	200	µgAl/l	0	24	33.51	50
Iron	37	200	µgFe/l	0	< 6	16.95	116
Manganese	37	50	µgMn/l	0	< 2	4.70	23
Copper	4	2	mgCu/l	0	0.00	0.01	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	37	50	µgCN/l	0	< 1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	0.65	0.80
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	1.38	3
Lead	37	10	µgPb/l	2.70	< 0.30	2.07	60.80

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer C

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	144		CFU/ml	0	0	2.67	145
Residual Disinfectant - Free	143		mg/l	0	< 0.04	0.37	0.75
Residual Disinfectant - Total	144		mg/l	0	0.06	0.45	0.79
Conductivity	37	2500	µS/cm	0	82	88.57	96
Chloride	37	250	mgCl/l	0	5	6.54	11
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	37	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	37	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	37	100	µg/l	0	23.10	41.06	66.70
Chlorate	5	0.25	mg/l	0	< 0.01	0.01	0.03
Chlorite	36	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	37	60	µg/l	0	13.50	25.05	50.10
1,2 Dichloroethane	37	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	37	1	µg/l	0	< 0.08	< 0.08	< 0.08

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer C

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Bromate	36	10	µgBrO3/l	0	< 0.90	0.92	1.60
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	4	50	mgNO3/l	0	< 0.50	0.68	0.88
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13