

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer Camps B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	40	4	NTU	0	< 0.30	0.31	0.60
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	0	7.50	7.79	8
Total organic carbon	40		mgC/l	0	0.90	1.30	2
Aluminium	40	200	µgAl/l	0	13	33.95	80
Iron	40	200	µgFe/l	0	< 6	14.48	146
Manganese	40	50	µgMn/l	0	< 2	4.53	30
Cyanide	40	50	µgCN/l	0	< 1	1.03	2
Lead	40	10	µgPb/l	0	< 0.30	0.36	1.50
Coliform Bacteria (Total coliforms)	154	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	154	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	155		CFU/ml	0	0	5.07	300
Residual Disinfectant - Free	156		mg/l	0	< 0.04	0.44	1.29
Residual Disinfectant - Total	156		mg/l	0	0.08	0.52	1.67
Conductivity	40	2500	µS/cm	0	83	91.33	99
Chloride	40	250	mgCl/l	0	5	6.88	8

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Daer Camps B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	40	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	40	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	40	100	µg/l	0	24.30	43.46	68.20
Chlorate	40	0.25	mg/l	0	< 0.01	0.03	0.18
Chlorite	40	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	40	60	µg/l	0	18.20	30.82	54.70
1,2-Dichloroethane	40	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	40	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	40	10	µgBrO3/l	0	< 0.90	0.90	0.90
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	4	250	mgSO4/l	0	14	16.93	19.50
Sodium	4	200	mgNa/l	0	3.60	3.83	3.90
Nitrate	4	50	mgNO3/l	0	< 0.50	1.33	3.38
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.02	0.07
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	0.00	0.00	0.01
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	0.03	0.06
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Daer Camps B**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12