

# Scottish Water

## Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Forehill

Page 1 of 3

| Parameter Name            | No. of Results | PCV | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|---------------------------|----------------|-----|------------------|-------------------------|--------|--------|--------|
| Colour                    | 49             | 20  | mg/l Pt/Co       | 0                       | < 2    | < 2    | < 2    |
| Turbidity                 | 49             | 4   | NTU              | 0                       | < 0.30 | 0.30   | 0.30   |
| Odour                     | 49             | 0   | Dilution number  | 0                       | 0      | 0      | 0      |
| Taste                     | 49             | 0   | Dilution number  | 0                       | 0      | 0      | 0      |
| Hydrogen ion (pH)         | 49             | 9.5 | pH units         | 0                       | 7.70   | 7.92   | 8.60   |
| Sulphate                  | 4              | 250 | mgSO4/l          | 0                       | 45.80  | 57.03  | 61.70  |
| Sodium                    | 4              | 200 | mgNa/l           | 0                       | 25.40  | 26.30  | 27.10  |
| Aluminium                 | 49             | 200 | µgAl/l           | 0                       | < 8    | 8.31   | 11     |
| Iron                      | 49             | 200 | µgFe/l           | 0                       | < 6    | 9.27   | 28     |
| Manganese                 | 49             | 50  | µgMn/l           | 0                       | < 2    | < 2    | < 2    |
| Copper                    | 4              | 2   | mgCu/l           | 0                       | 0.00   | 0.02   | 0.05   |
| Arsenic                   | 4              | 10  | µgAs/l           | 0                       | < 0.20 | < 0.20 | < 0.20 |
| Cadmium                   | 4              | 5   | µgCd/l           | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Cyanide                   | 4              | 50  | µgCN/l           | 0                       | < 1    | 1      | 1      |
| Chromium                  | 4              | 50  | µgCr/l           | 0                       | < 0.60 | < 0.60 | < 0.60 |
| Nickel                    | 4              | 20  | µgNi/l           | 0                       | < 0.80 | 0.88   | 1.10   |
| Lead                      | 4              | 10  | µgPb/l           | 0                       | < 0.30 | 0.68   | 1.80   |
| Antimony                  | 4              | 5   | µgSb/l           | 0                       | < 0.40 | < 0.40 | < 0.40 |
| Selenium                  | 4              | 10  | µgSe/l           | 0                       | < 1.20 | < 1.20 | < 1.20 |
| PAH - Sum Of 4 Substances | 4              | 0.1 | µg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Forehill

Page 2 of 3

| Parameter Name                                         | No. of Results | PCV  | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|--------------------------------------------------------|----------------|------|------------------|-------------------------|--------|--------|--------|
| Coliform Bacteria (Total coliforms)                    | 84             | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| E. coli (Faecal coliforms)                             | 84             | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Enterococci (Faecal streptococci)                      | 49             | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Clostridium perfringens (Sulphite Reducing Clostridia) | 49             | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Colony Counts After 3 Days At 22øc                     | 84             |      | CFU/ml           | 0                       | 0      | 0.05   | 2      |
| Residual Disinfectant - Free                           | 84             |      | mg/l             | 0                       | 0.05   | 0.47   | 0.73   |
| Residual Disinfectant - Total                          | 84             |      | mg/l             | 0                       | 0.28   | 0.56   | 0.86   |
| Conductivity                                           | 49             | 2500 | µS/cm            | 0                       | 284    | 335.78 | 379    |
| Chloride                                               | 49             | 250  | mgCl/l           | 0                       | 34     | 40.45  | 49     |
| Boron                                                  | 4              | 1    | mgB/l            | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Benzo 3_4 Pyrene                                       | 4              | 0.01 | µg/l             | 0                       | < 0.00 | < 0.00 | < 0.00 |
| Gross Alpha Activity                                   | 4              |      | Bq/l             | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Gross Beta Activity                                    | 4              |      | Bq/l             | 0                       | 0.05   | 0.08   | 0.11   |
| Uranium                                                | 4              | 30   | µgU/l            | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Microcystin LR                                         | 49             | 1    | µg/l             | 0                       | < 0.05 | < 0.05 | < 0.05 |
| Pesticides - Total Substances                          | 4              | 0.5  | µg/l             | 0                       | 0      | 0      | 0      |
| BISPHENO L A                                           | 4              | 2.5  | µg/l             | 0                       | < 0.13 | < 0.13 | < 0.13 |
| 2 4-D                                                  | 4              | 0.1  | µg/l             | 0                       | < 0.01 | < 0.01 | < 0.01 |
| Dicamba                                                | 4              | 0.1  | µg/l             | 0                       | < 0.01 | < 0.01 | < 0.01 |
| MCPP(Mec oprop)                                        | 4              | 0.1  | µg/l             | 0                       | < 0.01 | < 0.01 | < 0.01 |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Forehill

Page 3 of 3

| Parameter Name                                           | No. of Results | PCV  | Units of Measure        | Results Failing PCV (%) | Min    | Mean   | Max    |
|----------------------------------------------------------|----------------|------|-------------------------|-------------------------|--------|--------|--------|
| MCPA                                                     | 4              | 0.1  | µg/l                    | 0                       | < 0.00 | < 0.00 | < 0.00 |
| MCPB                                                     | 4              | 0.1  | µg/l                    | 0                       | < 0.01 | < 0.01 | 0.02   |
| 2,4-Db                                                   | 4              | 0.1  | µg/l                    | 0                       | < 0.01 | < 0.01 | 0.02   |
| Nitrate                                                  | 3              | 50   | mgNO <sub>3</sub> /l    | 0                       | 17.80  | 20.83  | 23.45  |
| Nitrite                                                  | 4              | 0.5  | mgNO <sub>2</sub> /l    | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Nitrite/Nitrate formula                                  | 3              |      | Unitless                | 0                       | 0.36   | 0.42   | 0.47   |
| Ammonium (total)                                         | 4              | 0.5  | mg/l as NH <sub>4</sub> | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Total organic carbon                                     | 4              |      | mgC/l                   | 0                       | 0.70   | 0.75   | 0.80   |
| Fluoride                                                 | 4              | 1.5  | mgF/l                   | 0                       | < 0.12 | < 0.12 | < 0.12 |
| Tetrachloro methane                                      | 4              | 3    | µg/l                    | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances | 4              | 10   | µg/l                    | 0                       | < 0.52 | < 0.52 | < 0.52 |
| Total Trihalomethanes                                    | 4              | 100  | µg/l                    | 0                       | 14.10  | 22.18  | 25.30  |
| Chlorate                                                 | 4              | 0.25 | mg/l                    | 0                       | 0.02   | 0.03   | 0.04   |
| Chlorite                                                 | 4              | 0.25 | mg/l                    | 0                       | < 0.02 | < 0.02 | < 0.02 |
| HAA5 Total                                               | 4              | 60   | µg/l                    | 0                       | 4.70   | 7.43   | 10.50  |
| 1,2-Dichloroethane                                       | 4              | 3    | µg/l                    | 0                       | < 0.09 | < 0.09 | < 0.09 |
| Benzene                                                  | 4              | 1    | µg/l                    | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Bromate                                                  | 4              | 10   | µgBrO <sub>3</sub> /l   | 0                       | < 0.90 | 0.93   | 1      |
| Mercury                                                  | 4              | 1    | µgHg/l                  | 0                       | < 0.02 | < 0.02 | < 0.02 |