

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glencorse C

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	49	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	49	4	NTU	0	< 0.30	0.30	0.30
Odour	49	0	Dilution number	0	0	0	0
Taste	49	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	49	9.5	pH units	0	7.70	8.05	8.50
Nitrate	4	50	mgNO ₃ /l	0	1.12	1.40	1.90
Nitrite	49	0.5	mgNO ₂ /l	0	< 0.02	0.02	0.13
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.04	0.07
Ammonium (total)	49	0.5	mg/l as NH ₄	0	0.20	0.27	0.32
Aluminium	49	200	µgAl/l	0	15	20.71	52
Iron	49	200	µgFe/l	2.04	< 6	21.71	300
Manganese	49	50	µgMn/l	0	4	6.57	29
Lead	50	10	µgPb/l	0	< 0.30	0.76	7.70
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	191	0	CFU/100ml	0.52	0	0.01	1
E. coli (Faecal coliforms)	191	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	49	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	49	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	191		CFU/ml	0	0	0.59	26
Residual Disinfectant - Free	192		mg/l	0	0.04	0.08	0.29

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glencorse C

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Total	192		mg/l	0	0.69	1.05	1.28
Conductivity	49	2500	µS/cm	0	80	84.53	93
Chloride	49	250	mgCl/l	0	5	6.53	8
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	49	0.25	mg/l	0	0.03	0.07	0.14
Chlorite	49	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	49	10	µgBrO3/l	0	< 0.90	0.96	1.80
Sulphate	4	250	mgSO4/l	0	10	10.65	11.70
Sodium	4	200	mgNa/l	0	4.70	4.78	4.90
Copper	4	2	mgCu/l	0	0.00	0.00	0.00
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1.75	2
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glencorse C

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
HAA5 Total	4	60	µg/l	0	2.50	4.83	7.20
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Total organic carbon	4		mgC/l	0	0.90	1.05	1.30
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	6.40	8.65	10.90
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13