

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	0.30	0.40
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.80	8.15	8.60
Nitrate	4	50	mgNO ₃ /l	0	0.58	0.84	1.43
Nitrite	4	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.01	0.02	0.03
Ammonium (total)	4	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	37		mgC/l	0	1	1.26	1.70
Aluminium	37	200	µgAl/l	2.70	16	53.59	809
Iron	37	200	µgFe/l	2.70	< 6	145.84	4873
Manganese	37	50	µgMn/l	2.70	< 2	12.16	338
Cyanide	37	50	µgCN/l	0	< 1	1	1
Lead	37	10	µgPb/l	0	< 0.30	0.34	0.80
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0.69	0	0.01	1
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colony Counts After 3 Days At 22øc	143		CFU/ml	0	0	1.59	77
Residual Disinfectant - Free	145		mg/l	0	< 0.04	0.46	0.84
Residual Disinfectant - Total	145		mg/l	0	0.11	0.54	1.10
Conductivity	37	2500	µS/cm	0	105	125.19	148
Chloride	37	250	mgCl/l	0	5	5.76	6
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	37	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	37	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	37	100	µg/l	0	21.40	37.77	52.60
Chlorate	36	0.25	mg/l	0	0.02	0.08	0.21
HAA5 Total	37	60	µg/l	0	13.50	23.74	34.20
1_2 Dichloroeth ane	37	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	37	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	37	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	4	250	mgSO4/l	0	19.60	22.93	27.60
Sodium	4	200	mgNa/l	0	5.20	5.78	6.90
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.23	0.30

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon A

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Pesticides - Total Substances	4	0.5	µg/l	0	0	0.01	0.03
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
2 4-D	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	4	0.1	µg/l	0	< 0.01	0.01	0.03
MCPP(Mecoprop)	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	4	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
2 4-Db	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02