

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	55	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	55	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	55	0	Dilution number	0	0	0	0
Taste	55	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	55	9.5	pH units	0	7.70	8.11	8.60
Sulphate	4	250	mgSO ₄ /l	0	17.60	21.53	26.80
Sodium	4	200	mgNa/l	0	5	5.63	6.30
Total organic carbon	55		mgC/l	0	0.90	1.26	1.70
Aluminium	55	200	µgAl/l	0	14	34.11	68
Iron	55	200	µgFe/l	0	< 6	18.33	118
Manganese	55	50	µgMn/l	0	< 2	3.25	19
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.23	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	55	50	µgCN/l	0	< 1	1.02	2
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	55	10	µgPb/l	0	< 0.30	0.44	3.80

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	216	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	216	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	55	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	55	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	215		CFU/ml	0	0	0.28	14
Residual Disinfectant - Free	216		mg/l	0	0.09	0.52	0.86
Residual Disinfectant - Total	215		mg/l	0	0.12	0.61	1.03
Conductivity	55	2500	µS/cm	0	107	125.89	158
Chloride	55	250	mgCl/l	0	5	5.84	7
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	55	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	55	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	55	100	µg/l	0	22.30	37.87	56.80
Chlorate	55	0.25	mg/l	0	0.02	0.08	0.19
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Glendevon B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
HAA5 Total	55	60	µg/l	0	7.40	25.61	41.30
1_2 Dichloroethane	55	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	55	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	4	10	µgBrO3/l	0	< 0.90	0.98	1.20
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	55	1	µg/l	0	< 0.05	< 0.05	< 0.05
2_4-D	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPP(Mecoprop)	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	4	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	4	0.1	µg/l	0	< 0.01	< 0.01	0.02
2_4-Db	4	0.1	µg/l	0	< 0.01	< 0.01	0.02
Nitrate	3	50	mgNO3/l	0	< 0.50	0.75	1.18
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13