

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	40	4	NTU	0	< 0.30	0.30	0.30
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	0	7.20	7.59	7.90
Total organic carbon	40		mgC/l	0	0.70	1.20	1.80
Aluminium	40	200	µgAl/l	0	< 8	12.68	29
Iron	40	200	µgFe/l	0	< 6	18.75	63
Manganese	40	50	µgMn/l	0	< 2	2.55	6
Cyanide	40	50	µgCN/l	0	< 1	1.03	2
Lead	40	10	µgPb/l	0	< 0.30	0.58	3.90
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	156	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	156	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	155		CFU/ml	0	0	0.91	61
Residual Disinfectant - Free	157		mg/l	0	< 0.04	0.47	0.85
Residual Disinfectant - Total	157		mg/l	0	0.07	0.57	0.95
Conductivity	40	2500	µS/cm	0	150	197.23	286

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	40	250	mgCl/l	0	7	9.73	12
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	40	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	40	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	40	100	µg/l	0	9.80	26.89	47.30
Chlorate	40	0.25	mg/l	0	0.02	0.08	0.22
Chlorite	40	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	40	60	µg/l	0	6.30	15.51	35.60
1_2 Dichloroethane	40	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	40	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	40	10	µgBrO3/l	0	< 0.90	0.97	2
Microcystin LR	40	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	30.60	32.10	35.80
Sodium	4	200	mgNa/l	0	7.10	7.65	9
Nitrate	4	50	mgNO3/l	0	0.90	12.29	19.17
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.25	0.38
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.02	0.04
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH A

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Arsenic	4	10	µgAs/l	0	0.20	0.35	0.50
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.03
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	0.85	1
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Pesticides - Total Substances	4	0.5	µg/l	0	0	0.01	0.04
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
2,4-D	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	4	0.1	µg/l	0	< 0.01	0.02	0.04
MCPP(Mecoprop)	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	4	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	4	0.1	µg/l	0	< 0.01	< 0.01	0.02
2,4-Db	4	0.1	µg/l	0	< 0.01	< 0.01	0.02