

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	28	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	28	4	NTU	0	< 0.30	0.30	0.40
Odour	28	0	Dilution number	0	0	0	0
Taste	28	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	28	9.5	pH units	0	7.10	7.43	7.80
Sulphate	28	250	mgSO ₄ /l	0	26.80	31.98	40.50
Nitrate	3	50	mgNO ₃ /l	0	1.59	2.64	4.19
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0.03	0.05	0.08
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	28		mgC/l	0	1.20	1.42	1.70
Aluminium	28	200	µgAl/l	0	< 8	18.14	46
Iron	28	200	µgFe/l	10.71	< 6	89.18	807
Manganese	28	50	µgMn/l	0	< 2	3.93	11
Cyanide	28	50	µgCN/l	0	< 1	1.07	2
Lead	28	10	µgPb/l	0	< 0.30	0.46	2.10
PAH - Sum Of 4 Substances	28	0.1	µg/l	0	< 0.02	< 0.02	0.03
Coliform Bacteria (Total coliforms)	108	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	108	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	28	0	CFU/100ml	0	0	0	0

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Clostridium perfringens (Sulphite Reducing Clostridia)	28	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	107		CFU/ml	0	0	0.77	54
Residual Disinfectant - Free	108		mg/l	0	< 0.04	0.42	0.89
Residual Disinfectant - Total	108		mg/l	0	0.05	0.51	1.20
Conductivity	28	2500	µS/cm	0	144	162.75	203
Chloride	28	250	mgCl/l	0	7	8.79	10
Benzo 3_4 Pyrene	28	0.01	µg/l	0	< 0.00	< 0.00	0.00
Tetrachloro methane	29	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	29	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	29	100	µg/l	0	20.90	32.38	45.20
Chlorate	28	0.25	mg/l	0	0.03	0.09	0.21
Chlorite	28	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	28	60	µg/l	0	12.40	21.52	29.40
1_2 Dichloroethane	29	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	28	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	28	10	µgBrO3/l	0	< 0.90	0.91	1.30
Microcystin LR	28	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	28	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sodium	3	200	mgNa/l	0	6.90	7.60	8.90
Copper	3	2	mgCu/l	0	< 0.00	0.05	0.15

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = GLENFARG KWOODBH B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	0.20	0.37	0.50
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Pesticides - Total Substances	3	0.5	µg/l	0	0	0	0
2 4-D	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
Dicamba	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPP(Mecoprop)	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
MCPA	3	0.1	µg/l	0	< 0.00	< 0.00	< 0.00
MCPB	3	0.1	µg/l	0	< 0.01	< 0.01	0.02
2 4-Db	3	0.1	µg/l	0	< 0.01	< 0.01	0.02