

# Scottish Water

## Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Greenock

Page 1 of 3

| Parameter Name       | No. of Results | PCV | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|----------------------|----------------|-----|------------------|-------------------------|--------|--------|--------|
| Colour               | 103            | 20  | mg/l Pt/Co       | 0                       | < 2    | 2      | 2      |
| Turbidity            | 103            | 4   | NTU              | 0                       | < 0.30 | 0.30   | 0.60   |
| Odour                | 103            | 0   | Dilution number  | 0                       | 0      | 0      | 0      |
| Taste                | 103            | 0   | Dilution number  | 0                       | 0      | 0      | 0      |
| Hydrogen ion (pH)    | 103            | 9.5 | pH units         | 0                       | 7.40   | 7.79   | 8.50   |
| Sulphate             | 6              | 250 | mgSO4/l          | 0                       | 24.20  | 29     | 32.80  |
| Sodium               | 6              | 200 | mgNa/l           | 0                       | 5.80   | 7.47   | 8      |
| Total organic carbon | 103            |     | mgC/l            | 0                       | 1.10   | 1.61   | 3.40   |
| Aluminium            | 103            | 200 | µgAl/l           | 0                       | < 8    | 12.26  | 28     |
| Iron                 | 103            | 200 | µgFe/l           | 0                       | < 6    | 11.24  | 51     |
| Manganese            | 103            | 50  | µgMn/l           | 0                       | < 2    | 2.88   | 13     |
| Copper               | 6              | 2   | mgCu/l           | 0                       | < 0.00 | 0.01   | 0.02   |
| Fluoride             | 6              | 1.5 | mgF/l            | 0                       | < 0.12 | < 0.12 | < 0.12 |
| Arsenic              | 6              | 10  | µgAs/l           | 0                       | < 0.20 | 0.22   | 0.30   |
| Cadmium              | 6              | 5   | µgCd/l           | 0                       | < 0.02 | 0.02   | 0.02   |
| Cyanide              | 103            | 50  | µgCN/l           | 0                       | < 1    | 1      | 1      |
| Chromium             | 6              | 50  | µgCr/l           | 0                       | < 0.60 | < 0.60 | < 0.60 |
| Mercury              | 6              | 1   | µgHg/l           | 0                       | < 0.02 | 0.03   | 0.09   |
| Nickel               | 6              | 20  | µgNi/l           | 0                       | < 0.80 | < 0.80 | < 0.80 |
| Lead                 | 103            | 10  | µgPb/l           | 0                       | < 0.30 | 0.33   | 1      |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Greenock

Page 2 of 3

| Parameter Name                                            | No. of Results | PCV  | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|-----------------------------------------------------------|----------------|------|------------------|-------------------------|--------|--------|--------|
| Antimony                                                  | 6              | 5    | µgSb/l           | 0                       | < 0.40 | < 0.40 | < 0.40 |
| Selenium                                                  | 6              | 10   | µgSe/l           | 0                       | < 1.20 | < 1.20 | < 1.20 |
| PAH - Sum Of 4 Substances                                 | 6              | 0.1  | µg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Coliform Bacteria (Total coliforms)                       | 239            | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| E. coli (Faecal coliforms)                                | 239            | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Enterococci (Faecal streptococci)                         | 103            | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Clostridium perfringens (Sulphite Reducing Clostridia)    | 103            | 0    | CFU/100ml        | 0                       | 0      | 0      | 0      |
| Colony Counts After 3 Days At 22øc                        | 239            |      | CFU/ml           | 0                       | 0      | 0.21   | 31     |
| Residual Disinfectant - Free                              | 240            |      | mg/l             | 0                       | 0.04   | 0.63   | 1.07   |
| Residual Disinfectant - Total                             | 240            |      | mg/l             | 0                       | 0.07   | 0.71   | 1.10   |
| Conductivity                                              | 103            | 2500 | µS/cm            | 0                       | 114    | 124.06 | 135    |
| Chloride                                                  | 103            | 250  | mgCl/l           | 0                       | 4      | 11.55  | 18     |
| Boron                                                     | 6              | 1    | mgB/l            | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Benzo 3_4 Pyrene                                          | 6              | 0.01 | µg/l             | 0                       | < 0.00 | < 0.00 | < 0.00 |
| Tetrachloro methane                                       | 103            | 3    | µg/l             | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances | 103            | 10   | µg/l             | 0                       | < 0.52 | < 0.52 | < 0.52 |
| Total Trihalometh anes                                    | 103            | 100  | µg/l             | 0                       | 25.70  | 51.02  | 99.50  |
| Chlorate                                                  | 103            | 0.25 | mg/l             | 0                       | 0.03   | 0.08   | 0.21   |
| Chlorite                                                  | 6              | 0.25 | mg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |
| HAA5 Total                                                | 103            | 60   | µg/l             | 0                       | 10.30  | 31.17  | 59     |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Greenock

Page 3 of 3

| Parameter Name          | No. of Results | PCV | Units of Measure        | Results Failing PCV (%) | Min    | Mean   | Max    |
|-------------------------|----------------|-----|-------------------------|-------------------------|--------|--------|--------|
| 1_2 Dichloroethane      | 103            | 3   | µg/l                    | 0                       | < 0.09 | < 0.09 | < 0.09 |
| Benzene                 | 103            | 1   | µg/l                    | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Bromate                 | 6              | 10  | µgBrO <sub>3</sub> /l   | 0                       | < 0.90 | < 0.90 | < 0.90 |
| Gross Alpha Activity    | 6              |     | Bq/l                    | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Gross Beta Activity     | 6              |     | Bq/l                    | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Uranium                 | 6              | 30  | µgU/l                   | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Nitrate                 | 5              | 50  | mgNO <sub>3</sub> /l    | 0                       | < 0.50 | 0.53   | 0.59   |
| Nitrite                 | 6              | 0.5 | mgNO <sub>2</sub> /l    | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Nitrite/Nitrate formula | 5              |     | Unitless                | 0                       | 0      | 0.00   | 0.01   |
| Ammonium (total)        | 6              | 0.5 | mg/l as NH <sub>4</sub> | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Microcystin LR          | 6              | 1   | µg/l                    | 0                       | < 0.05 | < 0.05 | < 0.05 |
| BISPHENOL A             | 6              | 2.5 | µg/l                    | 0                       | < 0.13 | < 0.13 | < 0.13 |