

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Howden

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	31	20	mg/l Pt/Co	0	2	4.23	9
Turbidity	31	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	31	0	Dilution number	0	0	0	0
Taste	31	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	31	9.5	pH units	0	8	8.09	8.20
Nitrite	31	0.5	mgNO ₂ /l	6.45	< 0.02	0.08	0.67
Ammonium (total)	31	0.5	mg/l as NH ₄	0	< 0.04	0.30	0.39
Aluminium	30	200	µgAl/l	0	< 8	8.13	10
Iron	30	200	µgFe/l	0	< 6	8.17	44
Manganese	30	50	µgMn/l	0	< 2	2.17	5
Coliform Bacteria (Total coliforms)	72	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	72	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	31	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	31	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	71		CFU/ml	0	0	1.63	82
Residual Disinfectant - Free	72		mg/l	0	< 0.04	0.06	0.16
Residual Disinfectant - Total	72		mg/l	0	0.19	0.96	1.29
Conductivity	31	2500	µS/cm	0	147	184.35	210
Chloride	31	250	mgCl/l	0	11	13.03	15
Chlorate	31	0.25	mg/l	0	0.05	0.11	0.19

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Howden

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Microcystin LR	31	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	3	250	mgSO4/l	0	4.50	4.67	4.80
Sodium	3	200	mgNa/l	0	17.80	19.83	21.70
Total organic carbon	3		mgC/l	0	1.40	1.63	2
Copper	3	2	mgCu/l	0	0.00	0.00	0.01
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	3	50	µgCN/l	0	1	2	3
Chromium	3	50	µgCr/l	0	< 0.60	1.07	2
Mercury	3	1	µgHg/l	0	< 0.02	0.03	0.05
Nickel	3	20	µgNi/l	0	1	1.60	2.50
Lead	3	10	µgPb/l	0	< 0.30	0.30	0.30
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Howden

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Total Trihalomethanes	3	100	µg/l	0	13	13.67	15
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	0.04	0.04
Uranium	3	30	µgU/l	0	0.04	0.05	0.05
Nitrate	3	50	mgNO3/l	0	3.42	4.40	5.09
Nitrite/Nitrate formula	3		Unitless	0	0.07	0.09	0.10
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
HAA5 Total	3	60	µg/l	0	7	17.83	30.10