

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Invercannie

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	19	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	19	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	19	0	Dilution number	0	0	0	0
Taste	19	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	19	9.5	pH units	0	7.40	7.72	8.10
Nitrate	2	50	mgNO ₃ /l	0	1.35	2.23	3.11
Nitrite	19	0.5	mgNO ₂ /l	0	< 0.02	0.02	0.06
Nitrite/Nitrate formula	2		Unitless	0	0.03	0.05	0.06
Ammonium (total)	19	0.5	mg/l as NH ₄	0	0.26	0.34	0.42
Aluminium	19	200	µgAl/l	0	< 8	20.95	41
Iron	19	200	µgFe/l	0	< 6	12.05	27
Manganese	19	50	µgMn/l	0	2	3.53	6
Lead	19	10	µgPb/l	5.26	< 0.30	2.36	36.10
Coliform Bacteria (Total coliforms)	72	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	72	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	19	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	19	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	72		CFU/ml	0	0	0.29	15
Residual Disinfectant - Free	71		mg/l	0	< 0.04	0.08	0.60
Residual Disinfectant - Total	71		mg/l	0	0.07	1.23	1.87

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Invercannie

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Conductivity	19	2500	µS/cm	0	77	92.89	143
Chloride	19	250	mgCl/l	0	14	15.89	19
Chlorate	19	0.25	mg/l	10.53	0.04	0.13	0.28
HAA5 Total	3	60	µg/l	0	4.80	8.97	11.40
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	3.50	3.90	4.30
Sodium	3	200	mgNa/l	0	7.50	8.73	9.40
Copper	3	2	mgCu/l	0	0.14	0.26	0.49
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.04	0.07
Cyanide	3	50	µgCN/l	0	2	5	11
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	0.87	1
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	0.04	0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Invercannie

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Total organic carbon	3		mgC/l	0	0.80	0.93	1.10
Fluoride	3	1.5	mgF/l	0	< 0.12	0.12	0.12
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	3	100	µg/l	0	8.30	10.13	11.20
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroeth ane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05