

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Inverness

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	78	20	mg/l Pt/Co	0	< 2	2.09	3
Turbidity	78	4	NTU	0	< 0.30	0.31	0.50
Odour	77	0	Dilution number	0	0	0	0
Taste	77	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	78	9.5	pH units	0	7.40	8.23	8.60
Nitrate	5	50	mgNO ₃ /l	0	1.31	1.45	1.68
Nitrite	79	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.27
Nitrite/Nitrate formula	5		Unitless	0	0.03	0.03	0.03
Ammonium (total)	79	0.5	mg/l as NH ₄	0	0.17	0.31	0.37
Aluminium	79	200	µgAl/l	0	11	17.92	26
Iron	79	200	µgFe/l	1.27	< 6	15.15	208
Manganese	79	50	µgMn/l	0	< 2	2.04	4
Lead	79	10	µgPb/l	0	< 0.30	0.37	2.20
PAH - Sum Of 4 Substances	5	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	214	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	214	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	79	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	78	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	216		CFU/ml	0	0	0.82	91
Residual Disinfectant - Free	216		mg/l	0	< 0.04	0.07	0.70

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Inverness

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Total	216		mg/l	0	0.57	1.14	1.35
Conductivity	78	2500	µS/cm	0	85	99.65	103
Chloride	79	250	mgCl/l	0	16	17.14	18
Benzo 3_4 Pyrene	5	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	79	0.25	mg/l	0	0.02	0.07	0.17
HAA5 Total	5	60	µg/l	0	4.70	5.90	8.80
BISPHENO L A	5	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	5	250	mgSO4/l	0	2.90	2.98	3
Sodium	5	200	mgNa/l	0	8	8.22	8.40
Total organic carbon	5		mgC/l	0	1.70	1.78	2
Copper	5	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	5	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	5	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	5	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	5	50	µgCN/l	0	< 1	2	4
Chromium	5	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	5	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	5	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	5	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	5	10	µgSe/l	0	< 1.20	< 1.20	< 1.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Inverness

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Boron	5	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	5	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	5	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	5	100	µg/l	0	< 4.90	< 4.90	< 4.90
Chlorite	5	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroeth ane	5	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	5	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	5	10	µgBrO3/l	0	< 0.90	0.90	0.90
Gross Alpha Activity	5		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	5		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	5	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	5	1	µg/l	0	< 0.05	< 0.05	< 0.05