

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Killiecrankie

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	16	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	16	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	16	0	Dilution number	0	0	0	0
Taste	16	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	16	9.5	pH units	0	8.20	8.54	8.80
Aluminium	16	200	µgAl/l	0	< 8	22.69	60
Iron	16	200	µgFe/l	0	< 6	9.31	52
Manganese	16	50	µgMn/l	0	< 2	3.31	10
Coliform Bacteria (Total coliforms)	24	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	24	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	16	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	16	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	24		CFU/ml	0	0	7.54	179
Residual Disinfectant - Free	24		mg/l	0	0.24	0.52	0.83
Residual Disinfectant - Total	24		mg/l	0	0.29	0.57	0.86
Conductivity	16	2500	µS/cm	0	131	163.38	197
Chloride	16	250	mgCl/l	0	7	11.31	19
Microcystin LR	2	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	2	50	mgNO3/l	0	< 0.50	0.58	0.65
Nitrite	2	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Killiecrankie

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrite/Nitrate formula	2		Unitless	0	0	0.01	0.01
Ammonium (total)	2	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Total organic carbon	2		mgC/l	0	0.70	1.05	1.40
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	2	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	2	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	2	100	µg/l	0	17.40	28.60	39.80
HAA5 Total	2	60	µg/l	0	10.80	20.45	30.10
1_2 Dichloroethane	2	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	2	1	µg/l	0	< 0.08	< 0.08	< 0.08
Sulphate	2	250	mgSO4/l	0	7.70	13.70	19.70
Sodium	2	200	mgNa/l	0	13.10	13.10	13.10
Copper	2	2	mgCu/l	0	0.01	0.01	0.01
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	2	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	2	50	µgCN/l	0	< 1	1	1
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Killiecrankie**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	2	10	µgPb/l	0	< 0.30	0.95	1.60
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	2	0.25	mg/l	0	< 0.01	0.01	0.02
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13