

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Kirbister Orkney

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	16	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	16	4	NTU	0	< 0.30	0.31	0.40
Odour	16	0	Dilution number	0	0	0	0
Taste	16	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	16	9.5	pH units	0	7.90	8.06	8.30
Nitrite	16	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.17
Ammonium (total)	16	0.5	mg/l as NH ₄	0	0.18	0.28	0.35
Aluminium	16	200	µgAl/l	0	9	13.19	22
Iron	16	200	µgFe/l	0	< 6	6.06	7
Manganese	16	50	µgMn/l	0	< 2	3.63	13
Lead	16	10	µgPb/l	0	< 0.30	0.36	1.10
Coliform Bacteria (Total coliforms)	36	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	36	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	16	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	16	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	36		CFU/ml	0	0	0.39	5
Residual Disinfectant - Free	36		mg/l	0	< 0.04	0.06	0.17
Residual Disinfectant - Total	36		mg/l	0	0.52	0.96	1.38
Conductivity	16	2500	µS/cm	0	396	429.56	489
Chloride	16	250	mgCl/l	0	42	46.94	53

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Kirbister Orkney

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Microcystin LR	16	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	2	50	mgNO ₃ /l	0	0.64	1.46	2.27
Nitrite/Nitrate formula	2		Unitless	0	0.05	0.06	0.07
Total organic carbon	2		mgC/l	0	2.10	2.65	3.20
Pesticides - Total Substances	1	0.5	µg/l	0	0.02	0.02	0.02
Tetrachloromethane	2	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloroethene/Trichloroethene - Sum Of 2 Substances	2	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	2	100	µg/l	0	25.80	48.75	71.70
HAA5 Total	1	60	µg/l	0	9.90	9.90	9.90
1,2-Dichloroethane	2	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	2	1	µg/l	0	< 0.08	< 0.08	< 0.08
Dicamba	2	0.1	µg/l	0	< 0.01	0.01	0.02
Sulphate	2	250	mgSO ₄ /l	0	56.60	65.65	74.70
Sodium	2	200	mgNa/l	0	46.40	48.15	49.90
Copper	2	2	mgCu/l	0	0.01	0.03	0.06
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	2	10	µgAs/l	0	0.20	0.25	0.30
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	2	50	µgCN/l	0	5	5	5

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Kirbister Orkney

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	2	1	mgB/l	0	< 0.02	0.02	0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	2	0.25	mg/l	0	0.11	0.14	0.17
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	0.04	0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04