

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lerwick Shetland

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	2	2.95	5
Turbidity	22	4	NTU	0	< 0.30	0.30	0.40
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.50	8.08	9.10
Nitrite	22	0.5	mgNO ₂ /l	0	< 0.02	0.02	0.02
Ammonium (total)	22	0.5	mg/l as NH ₄	0	0.22	0.28	0.34
Total organic carbon	22		mgC/l	0	1.90	2.34	2.80
Aluminium	22	200	µgAl/l	0	14	24.45	43
Iron	22	200	µgFe/l	0	8	52.77	132
Manganese	22	50	µgMn/l	9.09	3	13.77	72
Cyanide	22	50	µgCN/l	0	< 1	2.91	5
Lead	22	10	µgPb/l	4.55	< 0.30	2.40	43
Coliform Bacteria (Total coliforms)	36	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	36	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	36		CFU/ml	0	0	0.92	19
Residual Disinfectant - Free	36		mg/l	0	< 0.04	0.06	0.16
Residual Disinfectant - Total	36		mg/l	0	0.62	1.01	1.26

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lerwick Shetland

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Conductivity	22	2500	µS/cm	0	264	271.82	289
Chloride	22	250	mgCl/l	0	44	47.36	50
Tetrachloro methane	22	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	22	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	22	100	µg/l	0	21.80	29.44	43
Chlorite	21	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	22	60	µg/l	0	8.30	14.61	21.40
1_2 Dichloroethane	22	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	22	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	21	10	µgBrO3/l	0	< 0.90	1.18	6.50
Microcystin LR	22	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	3	250	mgSO4/l	0	42.60	45.57	48.40
Sodium	3	200	mgNa/l	0	27.30	29.13	30.10
Nitrate	3	50	mgNO3/l	0	< 0.50	0.81	1.22
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Copper	3	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.03
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lerwick Shetland

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	0.83	0.90
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	3	0.25	mg/l	0	0.10	0.13	0.17
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13