

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lintrathen

Page 1 of 3

| Parameter Name                                         | No. of Results | PCV | Units of Measure        | Results Failing PCV (%) | Min    | Mean   | Max    |
|--------------------------------------------------------|----------------|-----|-------------------------|-------------------------|--------|--------|--------|
| Colour                                                 | 91             | 20  | mg/l Pt/Co              | 0                       | < 2    | < 2    | < 2    |
| Turbidity                                              | 91             | 4   | NTU                     | 0                       | < 0.30 | 0.30   | 0.40   |
| Odour                                                  | 91             | 0   | Dilution number         | 0                       | 0      | 0      | 0      |
| Taste                                                  | 91             | 0   | Dilution number         | 0                       | 0      | 0      | 0      |
| Hydrogen ion (pH)                                      | 91             | 9.5 | pH units                | 0                       | 7.40   | 7.77   | 8.60   |
| Nitrate                                                | 5              | 50  | mgNO <sub>3</sub> /l    | 0                       | 0.89   | 1.13   | 1.29   |
| Nitrite                                                | 5              | 0.5 | mgNO <sub>2</sub> /l    | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Nitrite/Nitrate formula                                | 5              |     | Unitless                | 0                       | 0.02   | 0.02   | 0.03   |
| Ammonium (total)                                       | 5              | 0.5 | mg/l as NH <sub>4</sub> | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Total organic carbon                                   | 91             |     | mgC/l                   | 0                       | 0.90   | 1.28   | 1.60   |
| Aluminium                                              | 91             | 200 | µgAl/l                  | 0                       | 13     | 32.30  | 89     |
| Iron                                                   | 91             | 200 | µgFe/l                  | 0                       | < 6    | 9.22   | 72     |
| Manganese                                              | 91             | 50  | µgMn/l                  | 2.20                    | < 2    | 6.71   | 135    |
| Cyanide                                                | 91             | 50  | µgCN/l                  | 0                       | < 1    | 1      | 1      |
| Lead                                                   | 91             | 10  | µgPb/l                  | 0                       | < 0.30 | 0.44   | 3      |
| Coliform Bacteria (Total coliforms)                    | 240            | 0   | CFU/100ml               | 0.83                    | 0      | 0.01   | 2      |
| E. coli (Faecal coliforms)                             | 240            | 0   | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Enterococci (Faecal streptococci)                      | 91             | 0   | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Clostridium perfringens (Sulphite Reducing Clostridia) | 91             | 0   | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Colony Counts After 3 Days At 22°C                     | 240            |     | CFU/ml                  | 0                       | 0      | 0.81   | 64     |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lintrathen

Page 2 of 3

| Parameter Name                                           | No. of Results | PCV  | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|----------------------------------------------------------|----------------|------|------------------|-------------------------|--------|--------|--------|
| Residual Disinfectant - Free                             | 241            |      | mg/l             | 0                       | < 0.04 | 0.37   | 0.83   |
| Residual Disinfectant - Total                            | 241            |      | mg/l             | 0                       | 0.04   | 0.46   | 0.87   |
| Conductivity                                             | 91             | 2500 | µS/cm            | 0                       | 83     | 87.97  | 98     |
| Chloride                                                 | 91             | 250  | mgCl/l           | 0                       | 5      | 5.97   | 7      |
| Tetrachloro methane                                      | 92             | 3    | µg/l             | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances | 92             | 10   | µg/l             | 0                       | < 0.52 | < 0.52 | < 0.52 |
| Total Trihalomethanes                                    | 92             | 100  | µg/l             | 0                       | 19.80  | 38.91  | 61.50  |
| Chlorate                                                 | 91             | 0.25 | mg/l             | 0                       | 0.03   | 0.07   | 0.16   |
| HAA5 Total                                               | 91             | 60   | µg/l             | 0                       | 2      | 23.54  | 42.30  |
| 1_2 Dichloroethane                                       | 92             | 3    | µg/l             | 0                       | < 0.09 | < 0.09 | < 0.09 |
| Benzene                                                  | 92             | 1    | µg/l             | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Sulphate                                                 | 5              | 250  | mgSO4/l          | 0                       | 12.40  | 13.32  | 15.30  |
| Sodium                                                   | 5              | 200  | mgNa/l           | 0                       | 5.30   | 5.54   | 5.90   |
| Copper                                                   | 5              | 2    | mgCu/l           | 0                       | < 0.00 | 0.01   | 0.02   |
| Fluoride                                                 | 5              | 1.5  | mgF/l            | 0                       | < 0.12 | < 0.12 | < 0.12 |
| Arsenic                                                  | 5              | 10   | µgAs/l           | 0                       | < 0.20 | 0.20   | 0.20   |
| Cadmium                                                  | 5              | 5    | µgCd/l           | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Chromium                                                 | 5              | 50   | µgCr/l           | 0                       | < 0.60 | < 0.60 | < 0.60 |
| Mercury                                                  | 5              | 1    | µgHg/l           | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Nickel                                                   | 5              | 20   | µgNi/l           | 0                       | < 0.80 | < 0.80 | < 0.80 |

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lintrathen

Page 3 of 3

| Parameter Name            | No. of Results | PCV  | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|---------------------------|----------------|------|------------------|-------------------------|--------|--------|--------|
| Antimony                  | 5              | 5    | µgSb/l           | 0                       | < 0.40 | < 0.40 | < 0.40 |
| Selenium                  | 5              | 10   | µgSe/l           | 0                       | < 1.20 | < 1.20 | < 1.20 |
| Boron                     | 5              | 1    | mgB/l            | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Chlorite                  | 5              | 0.25 | mg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Bromate                   | 5              | 10   | µgBrO3/l         | 0                       | < 0.90 | 0.90   | 0.90   |
| Gross Alpha Activity      | 5              |      | Bq/l             | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Gross Beta Activity       | 5              |      | Bq/l             | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Uranium                   | 5              | 30   | µgU/l            | 0                       | < 0.04 | < 0.04 | < 0.04 |
| Microcystin LR            | 5              | 1    | µg/l             | 0                       | < 0.05 | < 0.05 | < 0.05 |
| PAH - Sum Of 4 Substances | 5              | 0.1  | µg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Benzo 3_4 Pyrene          | 5              | 0.01 | µg/l             | 0                       | < 0.00 | < 0.00 | < 0.00 |
| BISPHENOL A               | 5              | 2.5  | µg/l             | 0                       | < 0.13 | < 0.13 | < 0.13 |