

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lochinvar

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	19	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	19	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	19	0	Dilution number	0	0	0	0
Taste	19	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	19	9.5	pH units	0	7.30	7.86	8.50
Total organic carbon	19		mgC/l	0	1.40	1.96	2.30
Aluminium	19	200	µgAl/l	0	9	28	55
Iron	19	200	µgFe/l	0	< 6	7.37	17
Manganese	19	50	µgMn/l	0	< 2	3.05	21
Coliform Bacteria (Total coliforms)	36	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	36	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	19	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	19	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	36		CFU/ml	0	0	0.08	2
Residual Disinfectant - Free	36		mg/l	0	0.10	0.38	0.57
Residual Disinfectant - Total	36		mg/l	0	0.17	0.48	0.70
Conductivity	19	2500	µS/cm	0	81	95.53	100
Chloride	19	250	mgCl/l	0	17	20.68	23
Tetrachloro methane	19	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	19	10	µg/l	0	< 0.52	< 0.52	< 0.52

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lochinvar

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Total Trihalomethanes	19	100	µg/l	0	26.50	62.11	85.90
1_2 Dichloroethane	19	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	19	1	µg/l	0	< 0.08	< 0.08	< 0.08
Sulphate	3	250	mgSO ₄ /l	0	1.60	1.70	1.80
Sodium	3	200	mgNa/l	0	5	5.17	5.30
Copper	3	2	mgCu/l	0	0.00	0.01	0.01
Arsenic	3	10	µgAs/l	0	< 0.20	0.27	0.30
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	19	50	µgCN/l	0	< 1	1.05	2
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	3	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Pesticides - Total Substances	5	0.5	µg/l	0	0	0	0
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	19	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	19	60	µg/l	0	18.60	31.36	49.70
Bromate	19	10	µgBrO ₃ /l	0	< 0.90	< 0.90	< 0.90

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lochinvar

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	19	1	µg/l	0	< 0.05	< 0.05	< 0.05
Dicamba	3	0.1	µg/l	0	< 0.01	< 0.01	< 0.01
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Nitrate	3	50	mgNO3/l	0	< 0.50	0.78	1.35
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.03
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorate	3	0.25	mg/l	0	< 0.01	0.03	0.06
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
	3			0	< 0.01	< 0.01	< 0.01
	3			0	< 0.01	< 0.01	< 0.01