

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lomond Hills BH Mix

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	0.30	0.30
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.70	8.01	8.20
Nitrate	4	50	mgNO ₃ /l	0	5.71	7.03	9.85
Nitrite	4	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.11	0.14	0.20
Ammonium (total)	4	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	37		mgC/l	0	0.60	1.07	1.70
Aluminium	37	200	µgAl/l	0	< 8	14.59	47
Iron	37	200	µgFe/l	0	< 6	11.41	45
Manganese	37	50	µgMn/l	0	< 2	2.76	22
Cyanide	37	50	µgCN/l	0	< 1	1	1
Lead	37	10	µgPb/l	5.41	< 0.30	1.48	18.60
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	144		CFU/ml	0	0	0.15	5

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lomond Hills BH Mix

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Free	145		mg/l	0	0.04	0.52	0.88
Residual Disinfectant - Total	145		mg/l	0	0.07	0.61	0.91
Conductivity	37	2500	µS/cm	0	158	305.05	359
Chloride	37	250	mgCl/l	0	7	12.24	14
Tetrachloro methane	37	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	37	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	37	100	µg/l	0	8.10	24.63	44.70
Chlorate	37	0.25	mg/l	0	0.02	0.07	0.20
Chlorite	37	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	37	60	µg/l	0	4.30	13.30	24.10
1,2 Dichloroethane	37	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	37	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	37	10	µgBrO3/l	0	< 0.90	0.90	1
Microcystin LR	37	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	27.20	29.63	32.10
Sodium	4	200	mgNa/l	0	7.80	12.55	15.40
Copper	4	2	mgCu/l	0	0.01	0.02	0.03
Arsenic	4	10	µgAs/l	0	0.20	0.23	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	0.63	0.70

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Lomond Hills BH Mix

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	0.03	0.07
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	0.04	0.05
Uranium	4	30	µgU/l	0	0.12	0.27	0.33
Fluoride	4	1.5	mgF/l	0	< 0.12	0.13	0.16
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	0.00	0.00
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13