

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield East

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	40	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	0	7.40	7.70	8
Nitrate	4	50	mgNO ₃ /l	0	1.75	2.32	2.61
Nitrite	40	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.34
Nitrite/Nitrate formula	4		Unitless	0	0.05	0.05	0.06
Ammonium (total)	40	0.5	mg/l as NH ₄	0	0.14	0.36	0.43
Total organic carbon	4		mgC/l	0	1	1.40	1.70
Aluminium	40	200	µgAl/l	0	10	23.45	52
Iron	40	200	µgFe/l	0	< 6	22.25	84
Manganese	40	50	µgMn/l	0	< 2	3.33	8
Lead	40	10	µgPb/l	0	< 0.30	0.50	3.30
Coliform Bacteria (Total coliforms)	156	0	CFU/100ml	0.64	0	0.01	1
E. coli (Faecal coliforms)	156	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	155		CFU/ml	0	0	1.08	65
Residual Disinfectant - Free	157		mg/l	0	< 0.04	0.08	0.55

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield East

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Total	157		mg/l	0	0.06	1.19	1.73
Conductivity	40	2500	µS/cm	0	85	105.65	135
Chloride	40	250	mgCl/l	0	15	18.13	23
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	10.80	13.20	18.10
Chlorate	40	0.25	mg/l	7.50	0.05	0.13	0.29
Chlorite	40	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	40	10	µgBrO3/l	0	< 0.90	0.93	1.30
Microcystin LR	40	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	4.50	4.98	5.60
Sodium	4	200	mgNa/l	0	8.60	9.05	9.50
Copper	4	2	mgCu/l	0	< 0.00	0.02	0.05
Fluoride	4	1.5	mgF/l	0	< 0.12	0.12	0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.25	0.40
Cadmium	4	5	µgCd/l	0	< 0.02	0.03	0.03
Cyanide	4	50	µgCN/l	0	< 1	2.25	5
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield East

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	4	60	µg/l	0	5.50	7.85	10.50
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Pesticides - Total Substances	5	0.5	µg/l	0	0	0.00	0.01
Asulam	4		µg/l	0	< 0.00	0.00	0.01
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01