

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield South

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	46	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	46	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	46	0	Dilution number	0	0	0	0
Taste	46	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	46	9.5	pH units	0	7.30	7.67	8
Sulphate	4	250	mgSO4/l	0	4.20	4.80	5.90
Sodium	4	200	mgNa/l	0	8.50	9.73	10.20
Nitrate	4	50	mgNO3/l	0	1.11	1.69	2.16
Nitrite	46	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.03	0.04
Ammonium (total)	46	0.5	mg/l as NH4	0	< 0.04	0.36	0.41
Aluminium	46	200	µgAl/l	0	< 8	21.39	46
Iron	46	200	µgFe/l	0	< 6	12.61	55
Manganese	46	50	µgMn/l	0	2	3.22	6
Copper	4	2	mgCu/l	0	< 0.00	0.01	0.04
Fluoride	4	1.5	mgF/l	0	< 0.12	0.13	0.16
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	2.25	3
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield South

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	46	10	µgPb/l	0	< 0.30	0.66	6.10
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	180	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	180	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	46	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	46	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	179		CFU/ml	0	0	3.46	276
Residual Disinfectant - Free	181		mg/l	0	< 0.04	0.07	0.34
Residual Disinfectant - Total	181		mg/l	0	0.04	1.22	1.97
Conductivity	46	2500	µS/cm	0	82	102.89	130
Chloride	46	250	mgCl/l	0	15	17.85	23
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	46	0.25	mg/l	13.04	0.04	0.14	0.29
Chlorite	46	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	4	60	µg/l	0	4.90	8.98	12.70
Bromate	46	10	µgBrO3/l	0	< 0.90	0.91	1.40
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Mannofield South

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Beta Activity	4		Bq/l	0	< 0.04	0.04	0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	46	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Total organic carbon	4		mgC/l	0	1	1.33	1.70
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	4	100	µg/l	0	9.10	14.73	24.30
1_2 Dichloroeth ane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Pesticides - Total Substances	5	0.5	µg/l	0	0	0	0
Asulam	4		µg/l	0	< 0.00	< 0.00	0.00
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01