

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Manse Street

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	10	20	mg/l Pt/Co	0	< 2	3.90	8
Turbidity	10	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	10	0	Dilution number	0	0	0	0
Taste	10	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	10	9.5	pH units	0	8	8.12	8.30
Total organic carbon	10		mgC/l	0	0.60	1.39	2.70
Aluminium	10	200	µgAl/l	0	< 8	12.50	40
Iron	10	200	µgFe/l	0	< 6	8.50	17
Manganese	10	50	µgMn/l	0	< 2	3.20	8
Cyanide	10	50	µgCN/l	0	< 1	1.80	3
Lead	10	10	µgPb/l	0	< 0.30	0.81	3.30
Coliform Bacteria (Total coliforms)	24	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	24	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	10	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	10	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	24		CFU/ml	0	0	0.88	17
Residual Disinfectant - Free	24		mg/l	0	0.04	0.34	0.87
Residual Disinfectant - Total	24		mg/l	0	0.39	0.89	1.13
Conductivity	10	2500	µS/cm	0	134	166.90	210
Chloride	10	250	mgCl/l	0	11	13.70	17

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Manse Street

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	10	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	10	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	10	100	µg/l	0	9.40	15.10	26.30
Chlorate	10	0.25	mg/l	10	0.04	0.14	0.38
HAA5 Total	10	60	µg/l	0	4.60	13.02	27.50
1_2 Dichloroethane	10	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	10	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	10	1	µg/l	0	< 0.05	< 0.05	< 0.05
Copper	2	2	mgCu/l	0	0.00	0.00	0.01
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	2	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Sulphate	2	250	mgSO4/l	0	3.90	4.20	4.50
Sodium	2	200	mgNa/l	0	11.80	14.20	16.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Manse Street

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrate	2	50	mgNO ₃ /l	0	< 0.50	1.99	3.47
Nitrite	2	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	2		Unitless	0	0	0.04	0.07
Ammonium (total)	2	0.5	mg/l as NH ₄	0	< 0.04	0.21	0.37
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO ₃ /l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	0.09	0.14
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00