

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie C2

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	22	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.30	7.92	8.50
Aluminium	22	200	µgAl/l	0	13	23.55	34
Iron	22	200	µgFe/l	0	< 6	7.55	14
Manganese	22	50	µgMn/l	0	< 2	< 2	< 2
Lead	22	10	µgPb/l	0	< 0.30	0.48	2.80
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	84	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	84	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	84		CFU/ml	0	0	1.05	70
Residual Disinfectant - Free	84		mg/l	0	0.25	0.51	0.77
Residual Disinfectant - Total	84		mg/l	0	0.35	0.61	0.95
Conductivity	22	2500	µS/cm	0	52	53.64	57
Chloride	22	250	mgCl/l	0	5	5.82	6
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie C2

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chlorate	22	0.25	mg/l	0	0.02	0.04	0.08
Sulphate	3	250	mgSO4/l	0	7.50	7.77	8
Sodium	3	200	mgNa/l	0	3.80	4	4.10
Copper	3	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	3	50	µgCN/l	0	1	1	1
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	0.05	0.11
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	3	60	µg/l	0	15.50	17.77	19.90
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie C2

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	3	50	mgNO ₃ /l	0	< 0.50	0.58	0.75
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	3		mgC/l	0	1.10	1.23	1.30
Tetrachloromethane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloroethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	31.30	38.53	44.50
1,2-Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
Pesticides - Total Substances	3	0.5	µg/l	0	0	0	0
	1			0	< 0.01	< 0.01	< 0.01
	1			0	< 0.01	< 0.01	< 0.01